

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Alféa Hybrid Duo Fioul/Oil A.I. 6	Reg. No.	012-SC0256-19
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Name of testing laboratory	RISE		
Subtype title	Alféa Hybrid Duo Fioul/Oil A.I. 6		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.1 kg		
Certification Date	27.06.2019		

Model: Alféa Hybrid Duo Fioul/Oil A.I. 6

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	6.00 kW	4.50 kW
El input	1.41 kW	1.79 kW
COP	4.26	2.51
Indoor water flow rate	1.05 m ³ /h	0.49 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	115 %
Prated	5.00 kW	5.00 kW
SCOP	4.30	2.95
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.60 kW	4.00 kW
COP Tj = -7°C	2.70	1.80
Pdh Tj = +2°C	2.80 kW	2.50 kW
COP Tj = +2°C	4.20	2.90
Pdh Tj = +7°C	2.30 kW	1.70 kW
COP Tj = +7°C	6.00	4.00
Pdh Tj = 12°C	2.30 kW	2.10 kW
COP Tj = 12°C	8.30	5.80
Pdh Tj = Tbiv	4.60 kW	4.00 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP $T_j = T_{biv}$	2.70	1.80
P _{dh} $T_j = TOL$	4.50 kW	3.50 kW
COP $T_j = TOL$	2.60	1.60
C _{dh}	0.90	0.90
WTOL	55 °C	55 °C
P _{off}	6 W	6 W
PTO	23 W	16 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.70 kW	1.00 kW
Annual energy consumption Q _{he}	2505 kWh	3180 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	88 %
Heating up time	01:45 h:min
Mixed water at 40°C	249 l
COP	3.00
Standby power input	32.0 W
Reference hot water temperature	54.0 °C