This information was generated by the HP KEYMARK database on 22 Jun 2022

Login

Summary of	WPF 27	Reg. No.	011-1W0276
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPF 27		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	7.2 kg		
Certification Date	24.01.2019		

Model: WPF 27

Configure model	
Model name	WPF 27
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	29.69 kW	26.69 kW
El input	6.12 kW	9.57 kW
COP	4.85	2.79

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	60 dB(A)	60 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	201 %	131 %
Prated	30.00 kW	27.00 kW
SCOP	5.23	3.48
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	29.70 kW	26.70 kW
COP Tj = +2°C	4.85	2.79
Pdh Tj = +7°C	30.00 kW	27.60 kW
COP Tj = +7°C	5.22	3.22
Pdh Tj = 12°C	30.50 kW	28.90 kW
COP Tj = 12°C	5.85	4.10
Pdh Tj = Tbiv	29.70 kW	26.70 kW
COP Tj = Tbiv	4.85	2.79
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	29.70 kW	26.70 kW

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.85	2.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	7587 kWh	10292 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	60 dB(A)	60 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	213 %	139 %
Prated	37.00 kW	34.00 kW

SCOP	5.53	3.68
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	30.20 kW	28.00 kW
COP Tj = -7°C	5.51	3.47
Pdh Tj = +2°C	30.50 kW	28.70 kW
COP Tj = +2°C	5.83	3.92
Pdh Tj = +7°C	30.60 kW	29.20 kW
COP Tj = +7°C	6.09	4.36
Pdh Tj = 12°C	30.70 kW	29.60 kW
COP Tj = 12°C	6.13	4.73
Pdh Tj = Tbiv	30.10 kW	27.60 kW
COP Tj = Tbiv	5.38	3.23
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	29.70 kW	26.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.85	2.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	7.26 kW	7.13 kW
Annual energy consumption Qhe	1646 kWh	22680 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	60 dB(A)	60 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	203 %	132 %
Prated	30.00 kW	27.00 kW
SCOP	5.28	3.50
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	29.80 kW	27.00 kW
COP Tj = -7°C	4.92	2.92
Pdh Tj = +2°C	30.10 kW	28.00 kW
COP Tj = +2°C	5.31	3.49

Pdh Tj = +7°C	30.40 kW	28.70 kW
COP Tj = +7°C	5.71	3.93
Pdh Tj = 12°C	30.70 kW	29.30 kW
COP Tj = 12°C	6.16	4.47
Pdh Tj = Tbiv	29.70 kW	26.70 kW
COP Tj = Tbiv	4.85	2.79
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	29.70 kW	26.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.85	2.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	11619 kWh	15758 kWh