

Page 1 of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Ideal Boiler Alféa Extensa A.I. 6	Reg. No.	012-SC0138-19
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT	·	
Name of testing laboratory	RISE		
Subtype title	Ideal Boiler Alféa Extensa A.I. 6		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.1 kg		
Certification Date	04.04.2020		



This information was generated by the HP KEYMARK database on 17 Dec 2020

Model: Alféa Extensa A.I. 6

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	4.50 kW
El input	1.41 kW	1.79 kW
СОР	4.26	2.51
Indoor water flow rate	1.05 m³/h	0.49 m³/h

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

Average Climate



 $$\operatorname{\textit{Page}}\xspace$ 3 of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	169 %	115 %
Prated	5.00 kW	5.00 kW
SCOP	4.30	2.95
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.60 kW	4.00 kW
COP Tj = -7°C	2.70	1.80
Pdh Tj = +2°C	2.80 kW	2.50 kW
COP Tj = +2°C	4.20	2.90
Pdh Tj = +7°C	2.30 kW	1.70 kW
COP Tj = +7°C	6.00	4.00
Pdh Tj = 12°C	2.30 kW	2.10 kW
COP Tj = 12°C	8.30	5.80
Pdh Tj = Tbiv	4.60 kW	4.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}4 of 4$ This information was generated by the HP KEYMARK database on 17 Dec 2020$

COP Tj = Tbiv	2.70	1.80
Pdh Tj = TOL	4.50 kW	3.50 kW
COP Tj = TOL	2.60	1.60
Cdh	0.90	0.90
WTOL	55 °C	55 °C
Poff	6 W	6 W
РТО	23 W	16 W
PSB	10 W	10 W
PCK	0 W	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.70 kW	1.00 kW
Annual energy consumption Qhe	2505 kWh	3180 kWh