

This information was generated by the HP KEYMARK database on 21 Jun 2022

[Login](#)

Summary of	AW-TDF190-H31	Reg. No.	ICIM-PDC-000034
Certificate Holder			
Name	Airwell Residential S.A.S.		
Address	10, rue du Fort de Saint Cyr	Zip	78180
City	Montigny le Bretonneux	Country	France
Certification Body	ICIM S.p.A.		
Subtype title	AW-TDF190-H31		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass of Refrigerant	1.1 kg		
Certification Date	20.06.2019		

This information was generated by the HP KEYMARK database on 21 Jun 2022

## Model: AW-TDF190-H31

Configure model	
Model name	AW-TDF190-H31
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	n/a
Any additional heat sources	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 12102-2</b>	
Sound power level indoor	51 dB(A)

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	115 %
COP	2.76
Heating up time	7:01 h:min
Standby power input	26.3 W
Reference hot water temperature	53.8 °C
Mixed water at 40°C	234 l

### Operating test

<b>EN 16147</b>	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed