

Page 1 of 10

This information was generated by the HP KEYMARK database on 22 Jun 2022

Login

Summary of	AEROTOP L 065 079 088	Reg. No.	ICIM-PDC-000099-00	
Certificate Holder				
Name	ELCO GmbH			
Address	Hohenzollernstrasse 31	Zip	72379	
City	Hechingen	Country	Germany	
Certification Body	ICIM S.p.A.	ICIM S.p.A.		
Subtype title	AEROTOP L 065 079 088			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R32			
Mass of Refrigerant	21 kg	21 kg		
Certification Date	30.03.2021	30.03.2021		
Testing basis	HP KEYMARK certification sch	HP KEYMARK certification scheme rules rev. 8		



Model: AEROTOP L 065

Configure model		
Model name	AEROTOP L 065	
Application	Heating (low temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	
Heat output	65.00 kW	
El input	40.10 kW	
СОР	4.29	

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



EN 12102-1	
	Low temperature
Sound power level outdoor	84 dB(A)

EN 14825		
	Low temperature	
η_{s}	160 %	
Prated	53.00 kW	
SCOP	4.08	
Tbiv	-7 °C	
TOL	-10 °C	
Pdh Tj = -7°C	44.70 kW	
$COPTj = -7^{\circ}C$	2.84	
Cdh Tj = -7 °C	0.90	
Pdh Tj = $+2$ °C	27.50 kW	
COP Tj = +2°C	4.19	
Cdh Tj = +2 °C	0.90	
Pdh Tj = $+7^{\circ}$ C	29.40 kW	
$COP Tj = +7^{\circ}C$	5.18	
Cdh Tj = +7 °C	0.90	
Pdh Tj = 12°C	35.10 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C	6.69
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	44.70 kW
COP Tj = Tbiv	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	40.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53
WTOL	55 °C
Poff	116 W
PTO	280 W
PSB	116 W
PCK	116 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	0 kWh



Model: AEROTOP L 079

Configure model			
Model name	AEROTOP L 079		
Application	Heating (low temp)		
Units	Outdoor		
Climate Zone	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	
Heat output	79.10 kW	
El input	40.10 kW	
СОР	4.17	

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



EN 12102-1	
	Low temperature
Sound power level outdoor	85 dB(A)

EN 14825	
	Low temperature
η_{s}	160 %
Prated	57.00 kW
SCOP	4.07
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	50.00 kW
COP Tj = -7°C	2.78
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	29.20 kW
$COP Tj = +2^{\circ}C$	4.11
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	30.40 kW
COP Tj = +7°C	5.29
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	35.50 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C	6.70
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	50.00 kW
COP Tj = Tbiv	2.78
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	45.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.55
WTOL	55 °C
Poff	116 W
PTO	280 W
PSB	116 W
PCK	116 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	0 kWh



Model: AEROTOP L 088

Configure model		
Model name	AEROTOP L 088	
Application	Heating (low temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	
Heat output	88.00 kW	
El input	40.10 kW	
СОР	4.15	

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



EN 12102-1	
	Low temperature
Sound power level outdoor	85 dB(A)

EN 14825	
	Low temperature
η_s	159 %
Prated	80.00 kW
SCOP	4.06
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	71.00 kW
COP Tj = -7°C	2.54
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	45.00 kW
$COP Tj = +2^{\circ}C$	4.23
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	30.80 kW
$COP Tj = +7^{\circ}C$	4.85
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	35.90 kW
	·

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 10 of 10

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP Tj = 12°C	6.84
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	71.00 kW
COP Tj = Tbiv	2.54
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	69.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30
WTOL	55 °C
Poff	116 W
PTO	280 W
PSB	116 W
PCK	116 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	0 kWh