Summary of	NIMBUS 70 S-T - ARIANEXT 70 S-T - AEROTOP SPLIT 07	Reg. No.	ICIM-PDC-000001
Certificate Holder			
Name	Ariston Thermo Group		
Address	Viale Aristide Merloni 45	Zip	I-60044
City	Fabriano (AN)	Country	Italy
Certification Body	ICIM S.p.A.		
Name of testing laboratory	-Transition Rules-		
Subtype title	NIMBUS 70 S-T - ARIANEXT 70 S-T - AEROTOP SPLIT 07		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	3.08 kg		
Certification Date	19.12.2017		

Model: AEROTOP SPLIT 07M-R

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95
Indoor water flow rate	1.11 m³/h	0.62 m³/h

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	7.88 kW	7.68 kW
η_s	191 %	133 %
Prated	6.40 kW	5.62 kW
SCOP	4.86	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.97 kW	6.80 kW
COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31

Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL	7.70 kW	6.75 kW
COP Tj = TOL	2.80	1.86
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

Pdesignh	4.85 kW	4.40 kW
η_s	233 %	153 %
Prated	6.30 kW	5.70 kW
SCOP	5.90	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.85 kW	4.40 kW
COP Tj = +2°C	4.16	2.36
Pdh Tj = +7°C	3.26 kW	3.01 kW
COP Tj = +7°C	5.48	3.34
Pdh Tj = 12°C	2.72 kW	2.62 kW
COP Tj = 12°C	7.46	5.50
Pdh Tj = Tbiv	4.85 kW	4.40 kW
COP Tj = Tbiv	4.16	2.36
Pdh Tj = TOL	4.85 kW	4.40 kW
COP Tj = TOL	4.16	2.36
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	11.71 kW	11.02 kW
η_s	151 %	118 %
Prated	4.80 kW	4.40 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW

COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL	5.52 kW	4.91 kW
COP Tj = TOL	2.23	1.52
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Qhe	7482 kWh	8977 kWh

Model: ARIANEXT PLUS 70 S-T LINK

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95
Indoor water flow rate	1.11 m³/h	0.62 m³/h

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	7.88 kW	7.68 kW
η_s	191 %	133 %
Prated	6.40 kW	5.62 kW
SCOP	4.86	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.97 kW	6.80 kW
COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31

Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL	7.70 kW	6.75 kW
COP Tj = TOL	2.80	1.86
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

Pdesignh	4.85 kW	4.40 kW
η_s	233 %	153 %
Prated	6.30 kW	5.70 kW
SCOP	5.90	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.85 kW	4.40 kW
COP Tj = +2°C	4.16	2.36
Pdh Tj = +7°C	3.26 kW	3.01 kW
COP Tj = +7°C	5.48	3.34
Pdh Tj = 12°C	2.72 kW	2.62 kW
COP Tj = 12°C	7.46	5.50
Pdh Tj = Tbiv	4.85 kW	4.40 kW
COP Tj = Tbiv	4.16	2.36
Pdh Tj = TOL	4.85 kW	4.40 kW
COP Tj = TOL	4.16	2.36
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	11.71 kW	11.02 kW
η_s	151 %	118 %
Prated	4.80 kW	4.40 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW

COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL	5.52 kW	4.91 kW
COP Tj = TOL	2.23	1.52
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Qhe	7482 kWh	8977 kWh

Model: ARIANEXT PLUS 70 S-T

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95
Indoor water flow rate	1.11 m³/h	0.62 m³/h

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	7.88 kW	7.68 kW
η_s	191 %	133 %
Prated	6.40 kW	5.62 kW
SCOP	4.86	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.97 kW	6.80 kW
COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31

Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL	7.70 kW	6.75 kW
COP Tj = TOL	2.80	1.86
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

Pdesignh	4.85 kW	4.40 kW
η_s	233 %	153 %
Prated	6.30 kW	5.70 kW
SCOP	5.90	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.85 kW	4.40 kW
COP Tj = +2°C	4.16	2.36
Pdh Tj = +7°C	3.26 kW	3.01 kW
COP Tj = +7°C	5.48	3.34
Pdh Tj = 12°C	2.72 kW	2.62 kW
COP Tj = 12°C	7.46	5.50
Pdh Tj = Tbiv	4.85 kW	4.40 kW
COP Tj = Tbiv	4.16	2.36
Pdh Tj = TOL	4.85 kW	4.40 kW
COP Tj = TOL	4.16	2.36
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	11.71 kW	11.02 kW
η_s	151 %	118 %
Prated	4.80 kW	4.40 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW

COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL	5.52 kW	4.91 kW
COP Tj = TOL	2.23	1.52
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Qhe	7482 kWh	8977 kWh

Model: NIMBUS PLUS 70 S-T NET

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95
Indoor water flow rate	1.11 m³/h	0.62 m³/h

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	7.88 kW	7.68 kW
η_s	191 %	133 %
Prated	6.40 kW	5.62 kW
SCOP	4.86	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.97 kW	6.80 kW
COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31

Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL	7.70 kW	6.75 kW
COP Tj = TOL	2.80	1.86
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

Pdesignh	4.85 kW	4.40 kW
η_s	233 %	153 %
Prated	6.30 kW	5.70 kW
SCOP	5.90	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.85 kW	4.40 kW
COP Tj = +2°C	4.16	2.36
Pdh Tj = +7°C	3.26 kW	3.01 kW
COP Tj = +7°C	5.48	3.34
Pdh Tj = 12°C	2.72 kW	2.62 kW
COP Tj = 12°C	7.46	5.50
Pdh Tj = Tbiv	4.85 kW	4.40 kW
COP Tj = Tbiv	4.16	2.36
Pdh Tj = TOL	4.85 kW	4.40 kW
COP Tj = TOL	4.16	2.36
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	11.71 kW	11.02 kW
η_s	151 %	118 %
Prated	4.80 kW	4.40 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW

COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL	5.52 kW	4.91 kW
COP Tj = TOL	2.23	1.52
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Qhe	7482 kWh	8977 kWh

Model: AEROTOP SPLIT 07M-CR

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95
Indoor water flow rate	1.11 m³/h	0.62 m³/h

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	7.88 kW	7.68 kW
η_s	191 %	133 %
Prated	6.40 kW	5.62 kW
SCOP	4.86	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.97 kW	6.80 kW
COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31

Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL	7.70 kW	6.75 kW
COP Tj = TOL	2.80	1.86
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

Pdesignh	4.85 kW	4.40 kW
η_s	233 %	153 %
Prated	6.30 kW	5.70 kW
SCOP	5.90	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.85 kW	4.40 kW
COP Tj = +2°C	4.16	2.36
Pdh Tj = +7°C	3.26 kW	3.01 kW
COP Tj = +7°C	5.48	3.34
Pdh Tj = 12°C	2.72 kW	2.62 kW
COP Tj = 12°C	7.46	5.50
Pdh Tj = Tbiv	4.85 kW	4.40 kW
COP Tj = Tbiv	4.16	2.36
Pdh Tj = TOL	4.85 kW	4.40 kW
COP Tj = TOL	4.16	2.36
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	11.71 kW	11.02 kW
η_s	151 %	118 %
Prated	4.80 kW	4.40 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW

COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL	5.52 kW	4.91 kW
COP Tj = TOL	2.23	1.52
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Qhe	7482 kWh	8977 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	108 %
COP	2.60
Heating up time	01:30 h:min
Standby power input	49.0 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	247 l

Warmer Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	118 %
COP	2.84
Heating up time	01:27 h:min
Standby power input	44.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	93 %
COP	2.25
Heating up time	01:22 h:min
Standby power input	54.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	244 l

Model: NIMBUS COMPACT 70 S-T NET

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95
Indoor water flow rate	1.11 m³/h	0.62 m³/h

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	7.88 kW	7.68 kW
η_s	191 %	133 %
Prated	6.40 kW	5.62 kW
SCOP	4.86	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.97 kW	6.80 kW
COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31

Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL	7.70 kW	6.75 kW
COP Tj = TOL	2.80	1.86
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

Pdesignh	4.85 kW	4.40 kW
η_s	233 %	153 %
Prated	6.30 kW	5.70 kW
SCOP	5.90	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.85 kW	4.40 kW
COP Tj = +2°C	4.16	2.36
Pdh Tj = +7°C	3.26 kW	3.01 kW
COP Tj = +7°C	5.48	3.34
Pdh Tj = 12°C	2.72 kW	2.62 kW
COP Tj = 12°C	7.46	5.50
Pdh Tj = Tbiv	4.85 kW	4.40 kW
COP Tj = Tbiv	4.16	2.36
Pdh Tj = TOL	4.85 kW	4.40 kW
COP Tj = TOL	4.16	2.36
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	11.71 kW	11.02 kW
η_s	151 %	118 %
Prated	4.80 kW	4.40 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW

COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL	5.52 kW	4.91 kW
COP Tj = TOL	2.23	1.52
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Qhe	7482 kWh	8977 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	108 %
COP	2.60
Heating up time	01:30 h:min
Standby power input	49.0 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	247 l

Warmer Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	118 %
COP	2.84
Heating up time	01:27 h:min
Standby power input	44.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

Colder Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	93 %
COP	2.25
Heating up time	01:22 h:min
Standby power input	54.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	244 l

Model: NIMBUS FLEX 70 S-T NET

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95
Indoor water flow rate	1.11 m³/h	0.62 m³/h

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	7.88 kW	7.68 kW
η_s	191 %	133 %
Prated	6.40 kW	5.62 kW
SCOP	4.86	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.97 kW	6.80 kW
COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31

Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL	7.70 kW	6.75 kW
COP Tj = TOL	2.80	1.86
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

Pdesignh	4.85 kW	4.40 kW
η_s	233 %	153 %
Prated	6.30 kW	5.70 kW
SCOP	5.90	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.85 kW	4.40 kW
COP Tj = +2°C	4.16	2.36
Pdh Tj = +7°C	3.26 kW	3.01 kW
COP Tj = +7°C	5.48	3.34
Pdh Tj = 12°C	2.72 kW	2.62 kW
COP Tj = 12°C	7.46	5.50
Pdh Tj = Tbiv	4.85 kW	4.40 kW
COP Tj = Tbiv	4.16	2.36
Pdh Tj = TOL	4.85 kW	4.40 kW
COP Tj = TOL	4.16	2.36
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
Pdesignh	11.71 kW	11.02 kW
η_s	151 %	118 %
Prated	4.80 kW	4.40 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW

COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL	5.52 kW	4.91 kW
COP Tj = TOL	2.23	1.52
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Qhe	7482 kWh	8977 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	108 %
COP	2.60
Heating up time	01:30 h:min
Standby power input	49.0 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	247 l

Warmer Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	118 %
COP	2.84
Heating up time	01:27 h:min
Standby power input	44.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	93 %
COP	2.25
Heating up time	01:22 h:min
Standby power input	54.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	244 l