

Login

Summary of	WWC 190 H/X	Reg. No.	041-K001-34	
Certificate Holder		<u> </u>		
Name	ait-deutschland Gmb	Н		
Address	Industriestr. 3	Zip	95359	
City	Kasendorf	Country	Germany	
Certification Body	BRE Global Limited	BRE Global Limited		
Subtype title	WWC 190 H/X	WWC 190 H/X		
Heat Pump Type	Water/Water			
Refrigerant	R407c	R407c		
Mass of Refrigerant	4.3 kg	4.3 kg		
Certification Date	06.09.2019			



Model: WWC 190H/X

Configure model		
Model name	WWC 190H/X	
Application	Heating (medium temp)	
Units	Indoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	18.60 kW	16.30 kW
El input	3.27 kW	4.81 kW
СОР	5.60	3.20

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Shutting on the heat transfer medium now	passeu
Complete power supply failure	passed
Starting and operating test	passed

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	53 dB(A)	53 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	234 %	179 %
Prated	18.30 kW	16.30 kW
SCOP	6.05	4.68
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	18.34 kW	16.60 kW
COP Tj = -7°C	5.66	3.63
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	18.56 kW	17.60 kW
COP Tj = +2°C	6.03	4.61
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	18.76 kW	18.20 kW
$COP Tj = +7^{\circ}C$	6.39	5.40
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	18.96 kW	18.80 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C	6.72	6.37
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	18.30 kW	16.30 kW
COP Tj = Tbiv	5.60	3.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	18.30 kW	16.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.60	3.39
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	6249 kWh	7193 kWh

Warmer Climate

mediu Mediu 181 %	m temperature
181 %	
kW 16.30 k	<w< td=""></w<>
4.73	
_	4.73



Page 5 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	18.30 kW	16.30 kW
$COPTj = +2^{\circ}C$	5.60	3.39
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = $+7^{\circ}$ C	18.52 kW	17.20 kW
$COP Tj = +7^{\circ}C$	5.95	4.18
Cdh Tj = $+7$ °C	1.00	1.00
Pdh Tj = 12°C	18.82 kW	18.40 kW
COP Tj = 12°C	6.51	5.71
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	18.30 kW	16.30 kW
COP Tj = Tbiv	5.60	3.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	18.30 kW	16.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.60	3.39
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
РСК	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4012 kWh	4604 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_{s}	241 %	186 %
Prated	18.30 kW	16.30 kW
SCOP	6.22	4.86
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	18.59 kW	17.40 kW
COP Tj = -7°C	6.09	4.39
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	18.77 kW	18.10 kW
COP Tj = +2°C	6.41	5.26
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	18.90 kW	18.60 kW
COP Tj = +7°C	6.65	6.04
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	18.94 kW	19.00 kW



 $$\operatorname{\textsc{Page}}\ 7$$ of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

	· · · · · · · · · · · · · · · · · · ·	
COP Tj = 12°C	6.59	6.70
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	18.30 kW	16.30 kW
COP Tj = Tbiv	5.60	3.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	18.30 kW	16.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.60	3.39
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	7258 kWh	8276 kWh
Pdh Tj = -15°C (if TOL<-20°C)	0.01	0.01
COP Tj = -15°C (if TOL $<$ -20°C)	0.01	0.01
Cdh Tj = -15 °C	1.00	1.00
1	T. Control of the Con	1