

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Jäspi Inverter M16	Reg. No.	012-C900023
Certificate Holder			
Name	Kaukora		
Address	Tuotekatu 11	Zip	FI-21200
City	Raisio	Country	Finland
Certification Body	RISE CERT		
Name of testing laboratory	AIT		
Subtype title	Jäspi Inverter M16		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	4 kg		
Certification Date	26.03.2020		
Testing basis	HP Keymark Scheme 2017		

## Model: Jäspi Inverter M16

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	7.03 kW	6.38 kW
El input	1.45 kW	2.04 kW
COP	4.85	3.13
Indoor water flow rate	1.21 m <sup>3</sup> /h	0.69 m <sup>3</sup> /h

### EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

This information was generated by the HP KEYMARK database on 17 Dec 2020

**EN 14825**

	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	176 %	134 %
Prated	14.50 kW	14.00 kW
SCOP	4.47	3.42
Tbiv	-8 °C	-8 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.90 kW	12.50 kW
COP Tj = -7°C	2.96	2.01
Pdh Tj = +2°C	7.90 kW	7.60 kW
COP Tj = +2°C	4.37	3.29
Pdh Tj = +7°C	5.10 kW	4.90 kW
COP Tj = +7°C	5.58	4.68
Pdh Tj = 12°C	6.40 kW	6.80 kW
COP Tj = 12°C	6.99	6.51
Pdh Tj = Tbiv	13.40 kW	12.70 kW
COP Tj = Tbiv	2.86	1.95
Pdh Tj = TOL	12.50 kW	11.00 kW
COP Tj = TOL	2.71	1.95
Cdh	0.97	0.98
WTOL	58 °C	58 °C

This information was generated by the HP KEYMARK database on 17 Dec 2020

Poff	2 W	2 W
PTO	25 W	16 W
PSB	15 W	15 W
PCK	20 W	20 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	2.00 kW	3.00 kW
Annual energy consumption Qhe	6702 kWh	8431 kWh