

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	Sphera EVO 2.0 Tower 250L 2.1, 3.1	Reg. No.	ICIM-PDC-000168
Certificate Holder			
Name	Clivet s.p.a.		
Address	Via camp lonc 25 c.ap.	Zip	I-32032
City	z.i. Villapaiera - Feltre (BL)	Country	Italy
Certification Body	ICIM S.p.A.		
Subtype title	Sphera EVO 2.0 Tower 250L 2.1, 3.1		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.5 kg		
Certification Date	10.06.2022		
Testing basis	HP KEYMARK certification scheme rules rev. n. 9		

Model: SQKN-YEE 1 TC A 250 + MiSAN-YEE 1 S 2.1

Configure model	
Model name	SQKN-YEE 1 TC A 250 + MiSAN-YEE 1 S 2.1
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.32 kW	4.08 kW
El input	0.80 kW	1.36 kW
COP	5.42	3.00

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	41 dB(A)
Sound power level outdoor	dB(A)	55 dB(A)

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 14825

	Low temperature	Medium temperature
η_s	202 %	130 %
Prated	5.36 kW	4.08 kW
SCOP	5.13	3.32
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.74 kW	3.61 kW
COP Tj = -7°C	3.15	2.02
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.05 kW	2.16 kW
COP Tj = +2°C	4.96	3.21
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.99 kW	1.54 kW
COP Tj = +7°C	6.81	4.43
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.45 kW	1.29 kW
COP Tj = 12°C	8.94	6.20
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	4.74 kW	3.61 kW
COP Tj = Tbiv	3.15	2.02

This information was generated by the HP KEYMARK database on 23 Jun 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	5.21 kW	3.91 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.86	1.68
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.900	0.900
WTOL	65 °C	65 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.15 kW	0.17 kW
Annual energy consumption Q_{he}	2161 kWh	2542 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	123 %
COP	2.85
Heating up time	3:10 h:min
Standby power input	56.0 W
Reference hot water temperature	56.0 °C
Mixed water at 40°C	255 l

Model: SQKN-YEE 1 TC A 250 + MiSAN-YEE 1 S 3.1

Configure model	
Model name	SQKN-YEE 1 TC A 250 + MiSAN-YEE 1 S 3.1
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.18 kW	5.94 kW
El input	1.19 kW	1.93 kW
COP	5.21	3.07

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	41 dB(A)
Sound power level outdoor	dB(A)	57 dB(A)

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 14825

	Low temperature	Medium temperature
η_s	203 %	139 %
Prated	6.23 kW	5.62 kW
SCOP	5.15	3.54
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.51 kW	4.97 kW
COP Tj = -7°C	3.13	2.12
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.30 kW	3.02 kW
COP Tj = +2°C	4.91	3.41
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.24 kW	2.00 kW
COP Tj = +7°C	7.11	4.82
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.45 kW	1.30 kW
COP Tj = 12°C	8.94	6.32
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.51 kW	4.97 kW
COP Tj = Tbiv	3.13	2.12

This information was generated by the HP KEYMARK database on 23 Jun 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	5.80 kW	5.27 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.70	1.64
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.900	0.900
WTOL	65 °C	65 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.43 kW	0.35 kW
Annual energy consumption Q_{he}	2502 kWh	3283 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	123 %
COP	2.85
Heating up time	3:10 h:min
Standby power input	56.0 W
Reference hot water temperature	56.0 °C
Mixed water at 40°C	255 l