

### Page 1 of 3

#### This information was generated by the HP KEYMARK database on 18 Mar 2022

#### Login

Summary of	VIESSMANN Vitocal 060-A Typ T0E-ze 060-A (250I)	Reg. No.	011-1W0339		
Certificate Holder					
Name	Viessmann Faulquemont SAS				
Address	Avenue André Gouy	Zip	F-57380		
City	Faulquemont	Country	France		
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH				
Subtype title	VIESSMANN Vitocal 060-A Typ T0E-ze 060-A (250I)				
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)				
Refrigerant	R1234ze				
Mass of Refrigerant	1.35 kg				
Certification Date	27.02.2020				



This information was generated by the HP KEYMARK database on 18 Mar 2022

# Model: Viessmann Vitocal 060-A Typ T0E-ze 060-A

Configure model			
Model name	Viessmann Vitocal 060-A Typ T0E-ze 060-A		
Units	Indoor		
Climate zone (for heating)	n/a		
Heat Source	Outdoor Air		
Any additional heat sources	n/a		

General Data		
Power supply	1x230V 50Hz	
Off-peak product	Yes	


## Domestic Hot Water (DHW)

## Operating test

EN 16147			
Temperature operating range	passed		
Safety devices checking test	passed		
Condensate draining	passed		

## **Average Climate**

EN 12102-2	
Sound power level indoor	53 dB(A)



24.0 W

53.3 °C

350 I



Standby power input

Mixed water at 40°C

Reference hot water temperature

# This information was generated by the HP KEYMARK database on 18 Mar 2022 EN 16147 Declared load profile 132 % Efficiency ηDHW COP 3.17 Heating up time 9:47 h:min