

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	SWAN 300	Reg. No.	ICIM-PDC-000007
Certificate Holder			
Name	Clivet s.p.a.		
Address	Via camp lonc 25 c.ap.	Zip	I-32032
City	z.i. Villapaiera - Feltre (BL)	Country	Italy
Certification Body	ICIM S.p.A.		
Name of testing laboratory	-Transition Rules-		
Subtype title	SWAN 300		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass Of Refrigerant	1.5 kg		
Certification Date	12.07.2018		
Testing basis	HP KEYMARK certification scheme rules rev. no. 4		

Model: SWAN 300

General Data

Power supply	1x230V 50Hz
Off-peak product	No

Domestic Hot Water (DHW)

Average Climate

EN 12102-2

Sound power level indoor	53 dB(A)
--------------------------	----------

EN 16147

Declared load profile	XL
Efficiency η_{DHW}	123 %
COP	3.01
Reference hot water temperature	53.1 °C
Mixed water at 40°C	354 l
Heating up time	7:49 h:min
Standby power input	30.6 W