

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	AEROTOP L 054 061	Reg. No.	ICIM-PDC-000098-00
Certificate Holder			
Name	ELCO GmbH		
Address	Hohenzollernstrasse 31	Zip	72379
City	Hechingen	Country	Germany
Certification Body	ICIM S.p.A.		
Subtype title	AEROTOP L 054 061		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	15 kg		
Certification Date	30.03.2021		
Testing basis	HP KEYMARK certification scheme rules rev. 8		

Model: AEROTOP L 054

Configure model	
Model name	AEROTOP L 054
Application	Heating (low temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2	
	Low temperature
Heat output	54.00 kW
El input	25.60 kW
COP	4.07

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature
Sound power level outdoor	83 dB(A)

EN 14825

	Low temperature
η_s	154 %
Prated	41.00 kW
SCOP	3.93
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	36.00 kW
COP Tj = -7°C	2.76
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	22.90 kW
COP Tj = +2°C	3.96
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	19.90 kW
COP Tj = +7°C	4.83
Cdh Tj = +7 °C	0.89
Pdh Tj = 12°C	24.40 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	7.05
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	36.00 kW
COP Tj = Tbiv	2.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	32.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.55
WTOL	55 °C
Poff	97 W
PTO	103 W
PSB	97 W
PCK	97 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	0 kWh

Model: AEROTOP L 061

Configure model	
Model name	AEROTOP L 061
Application	Heating (low temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2	
	Low temperature
Heat output	61.00 kW
El input	25.60 kW
COP	4.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature
Sound power level outdoor	83 dB(A)

EN 14825

	Low temperature
η_s	153 %
Prated	49.00 kW
SCOP	3.91
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	44.50 kW
COP Tj = -7°C	2.79
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	29.60 kW
COP Tj = +2°C	4.05
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	20.60 kW
COP Tj = +7°C	4.25
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	26.60 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	7.02
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	44.50 kW
COP Tj = Tbiv	2.79
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	41.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56
WTOL	55 °C
Poff	97 W
PTO	103 W
PSB	97 W
PCK	97 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	0 kWh