

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Samsung EHS TDM Plus R410A 12 kW & 16 kW (wall-mounted hydro unit)	Reg. No.	011-1W0379
Certificate Holder			
Name	Samsung Electronics Air Conditioner Europe B.V.		
Address	Evert van de Beekstraat 310	Zip	1118 CX
City	Schiphol	Country	Netherlands
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Samsung EHS TDM Plus R410A 12 kW & 16 kW (wall-mounted hydro unit)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	3.5 kg		
Certification Date	29.07.2020		
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 7		

Model: AE120MXTPEH/EU & AE160MNYDEH/EU

Configure model	
Model name	AE120MXTPEH/EU & AE160MNYDEH/EU
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.00 kW	10.72 kW
El input	2.72 kW	3.91 kW
COP	4.41	2.74

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	183 %	114 %
Prated	10.00 kW	8.00 kW
SCOP	4.65	2.92
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.80 kW	7.10 kW
COP Tj = -7°C	2.72	1.94
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.40 kW	4.30 kW
COP Tj = +2°C	4.69	2.86
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.50 kW	2.80 kW
COP Tj = +7°C	5.92	3.43
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.40 kW	5.00 kW
COP Tj = 12°C	7.85	5.52
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.00 kW	8.00 kW
COP Tj = Tbiv	2.41	1.79

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.00 kW	8.00 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.41	1.79
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.900	0.900
WTOL	55 °C	55 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	4516 kWh	5799 kWh

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	55 dB(A)	55 dB(A)
Sound power level outdoor	70 dB(A)	70 dB(A)

Warmer Climate

EN 14825

	Low temperature	Medium temperature
η_s	234 %	140 %

This information was generated by the HP KEYMARK database on 18 Mar 2022

Prated	10.00 kW	8.00 kW
SCOP	5.93	3.57
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.00 kW	8.70 kW
COP Tj = +2°C	3.19	2.03
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.70 kW	5.20 kW
COP Tj = +7°C	5.45	3.18
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.20 kW	3.50 kW
COP Tj = 12°C	7.24	4.41
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.00 kW	8.70 kW
COP Tj = Tbiv	3.19	2.03
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.19	2.03
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	22 W	22 W
PTO	22 W	22 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	2284 kWh	3054 kWh

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	55 dB(A)	55 dB(A)
Sound power level outdoor	70 dB(A)	70 dB(A)

Model: AE120MXTPGH/EU & AE160MNYDGH/EU

Configure model	
Model name	AE120MXTPGH/EU & AE160MNYDGH/EU
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.00 kW	10.72 kW
El input	2.72 kW	3.91 kW
COP	4.41	2.74

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	183 %	114 %
Prated	10.00 kW	8.00 kW
SCOP	4.65	2.92
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.80 kW	7.10 kW
COP Tj = -7°C	2.72	1.94
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.40 kW	4.30 kW
COP Tj = +2°C	4.69	2.86
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.50 kW	2.80 kW
COP Tj = +7°C	5.92	3.43
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.40 kW	5.00 kW
COP Tj = 12°C	7.85	5.52
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.00 kW	8.00 kW
COP Tj = Tbiv	2.41	1.79

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.00 kW	8.00 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.41	1.79
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.900	0.900
WTOL	55 °C	55 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	4516 kWh	5799 kWh

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	55 dB(A)	55 dB(A)
Sound power level outdoor	70 dB(A)	70 dB(A)

Warmer Climate

EN 14825

	Low temperature	Medium temperature
η_s	234 %	140 %

This information was generated by the HP KEYMARK database on 18 Mar 2022

Prated	10.00 kW	8.00 kW
SCOP	5.93	3.57
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.00 kW	8.70 kW
COP Tj = +2°C	3.19	2.03
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.70 kW	5.20 kW
COP Tj = +7°C	5.45	3.18
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.20 kW	3.50 kW
COP Tj = 12°C	7.24	4.41
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.00 kW	8.70 kW
COP Tj = Tbiv	3.19	2.03
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.19	2.03
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	22 W	22 W
PTO	22 W	22 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	2284 kWh	3054 kWh

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	55 dB(A)	55 dB(A)
Sound power level outdoor	70 dB(A)	70 dB(A)

Model: AE160MXTPEH/EU & AE160MNYDEH/EU

Configure model	
Model name	AE160MXTPEH/EU & AE160MNYDEH/EU
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	14.60 kW
El input	3.95 kW	5.32 kW
COP	4.05	2.74

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	55 dB(A)	55 dB(A)
Sound power level outdoor	73 dB(A)	73 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	182 %	119 %
Prated	11.00 kW	9.00 kW
SCOP	4.63	3.06
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.90 kW	7.80 kW
COP Tj = -7°C	2.65	2.01
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.00 kW	4.70 kW
COP Tj = +2°C	4.62	2.97
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.90 kW	3.50 kW
COP Tj = +7°C	6.12	3.73
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	4.40 kW	5.00 kW
COP Tj = 12°C	7.85	5.52
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.20 kW	8.80 kW
COP Tj = Tbiv	2.33	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.20 kW	8.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.33	1.83
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.20 kW	0.20 kW
Annual energy consumption Qhe	5086 kWh	6111 kWh

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	55 dB(A)	55 dB(A)
Sound power level outdoor	73 dB(A)	73 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	240 %	143 %
Prated	11.00 kW	9.00 kW
SCOP	6.07	3.65
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.80 kW	9.00 kW
COP Tj = +2°C	3.10	2.13
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	7.40 kW	5.90 kW
COP Tj = +7°C	5.45	3.21
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.40 kW	3.50 kW
COP Tj = 12°C	7.62	4.53
Cdh Tj = +12 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	11.80 kW	9.00 kW
COP Tj = Tbiv	3.10	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.80 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.10	2.13
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.20 kW	0.20 kW
Annual energy consumption Qhe	2494 kWh	3289 kWh

Model: AE160MXTPGH/EU & AE160MNYDGH/EU

Configure model	
Model name	AE160MXTPGH/EU & AE160MNYDGH/EU
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	14.60 kW
El input	3.95 kW	5.32 kW
COP	4.05	2.74

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	55 dB(A)	55 dB(A)
Sound power level outdoor	73 dB(A)	73 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	182 %	119 %
Prated	11.00 kW	9.00 kW
SCOP	4.63	3.06
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.90 kW	7.80 kW
COP Tj = -7°C	2.65	2.01
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.00 kW	4.70 kW
COP Tj = +2°C	4.62	2.97
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.90 kW	3.50 kW
COP Tj = +7°C	6.12	3.73
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	4.40 kW	5.00 kW
COP Tj = 12°C	7.85	5.52
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.20 kW	8.80 kW
COP Tj = Tbiv	2.33	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.20 kW	8.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.33	1.83
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.20 kW	0.20 kW
Annual energy consumption Qhe	5086 kWh	6111 kWh

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	55 dB(A)	55 dB(A)
Sound power level outdoor	73 dB(A)	73 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	240 %	143 %
Prated	11.00 kW	9.00 kW
SCOP	6.07	3.65
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.80 kW	9.00 kW
COP Tj = +2°C	3.10	2.13
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	7.40 kW	5.90 kW
COP Tj = +7°C	5.45	3.21
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.40 kW	3.50 kW
COP Tj = 12°C	7.62	4.53
Cdh Tj = +12 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	11.80 kW	9.00 kW
COP Tj = Tbiv	3.10	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.80 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.10	2.13
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.20 kW	0.20 kW
Annual energy consumption Qhe	2494 kWh	3289 kWh