

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	DAIKIN ALTHERMA HT SPLIT 14kW	Reg. No.	011-1W0257
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA HT SPLIT 14kW		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	4.5 kg		
Certification Date	12.06.2018		

Model: ERSQ014AY1 / EKHBRD014ADY17

Configure model	
Model name	ERSQ014AY1 / EKHBRD014ADY17
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.40 kW	14.00 kW
El input	3.87 kW	4.32 kW
COP	3.72	3.24

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	110 %	116 %
Prated	14.00 kW	13.00 kW
SCOP	2.81	2.98
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.50 kW	11.40 kW
COP Tj = -7°C	2.46	2.15
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.54 kW	7.61 kW
COP Tj = +2°C	2.82	3.02
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.03 kW	4.53 kW
COP Tj = +7°C	3.84	3.97
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	8.05 kW	4.68 kW
COP Tj = 12°C	4.29	4.67
Cdh Tj = +12 °C	1.00	0.94
Pdh Tj = Tbiv	11.50 kW	11.40 kW
COP Tj = Tbiv	2.54	2.15

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.40 kW	11.60 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.39	2.02
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	59 W	59 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.59 kW	1.40 kW
Annual energy consumption Q_{he}	9583 kWh	9000 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	60 dB(A)	60 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

Model: ERSQ014AV1 / EKHBRD014ADV17

Configure model	
Model name	ERSQ014AV1 / EKHBRD014ADV17
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.40 kW	14.00 kW
El input	3.87 kW	4.32 kW
COP	3.72	3.24

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	110 %	116 %
Prated	14.00 kW	13.00 kW
SCOP	2.81	2.98
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.50 kW	11.40 kW
COP Tj = -7°C	2.46	2.15
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.54 kW	7.61 kW
COP Tj = +2°C	2.82	3.02
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.03 kW	4.53 kW
COP Tj = +7°C	3.84	3.97
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	8.05 kW	4.68 kW
COP Tj = 12°C	4.29	4.67
Cdh Tj = +12 °C	1.00	0.94
Pdh Tj = Tbiv	11.50 kW	11.40 kW
COP Tj = Tbiv	2.54	2.15

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.40 kW	11.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.39	2.02
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	59 W	59 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.59 kW	1.40 kW
Annual energy consumption Qhe	9583 kWh	9000 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	60 dB(A)	60 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

Model: ERRQ014AY1 / EKHBRD014ADY17

Configure model	
Model name	ERRQ014AY1 / EKHBRD014ADY17
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.40 kW	14.00 kW
El input	3.87 kW	4.32 kW
COP	3.72	3.24

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	110 %	116 %
Prated	14.00 kW	13.00 kW
SCOP	2.81	2.98
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.50 kW	11.40 kW
COP Tj = -7°C	2.46	2.15
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.54 kW	7.61 kW
COP Tj = +2°C	2.82	3.02
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.03 kW	4.53 kW
COP Tj = +7°C	3.84	3.97
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	8.05 kW	4.68 kW
COP Tj = 12°C	4.29	4.67
Cdh Tj = +12 °C	1.00	0.94
Pdh Tj = Tbiv	11.50 kW	11.40 kW
COP Tj = Tbiv	2.54	2.15

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.40 kW	11.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.39	2.02
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	59 W	59 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.59 kW	1.40 kW
Annual energy consumption Qhe	9583 kWh	9000 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	60 dB(A)	60 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

Model: ERRQ014AV1 / EKHBRD014ADV17

Configure model	
Model name	ERRQ014AV1 / EKHBRD014ADV17
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.40 kW	14.00 kW
El input	3.87 kW	4.32 kW
COP	3.72	3.24

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	110 %	116 %
Prated	14.00 kW	13.00 kW
SCOP	2.81	2.98
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.50 kW	11.40 kW
COP Tj = -7°C	2.46	2.15
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.54 kW	7.61 kW
COP Tj = +2°C	2.82	3.02
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.03 kW	4.53 kW
COP Tj = +7°C	3.84	3.97
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	8.05 kW	4.68 kW
COP Tj = 12°C	4.29	4.67
Cdh Tj = +12 °C	1.00	0.94
Pdh Tj = Tbiv	11.50 kW	11.40 kW
COP Tj = Tbiv	2.54	2.15

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.40 kW	11.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.39	2.02
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	59 W	59 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.59 kW	1.40 kW
Annual energy consumption Qhe	9583 kWh	9000 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	60 dB(A)	60 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)