

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	F1345-30	Reg. No.	012-051
Certificate Holder			
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Subtype title	F1345-30		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass of Refrigerant	4 kg		

Model: F1345-30

Configure model	
Model name	F1345-30
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	30.72 kW	29.40 kW
El input	6.92 kW	10.20 kW
COP	4.44	2.90

Colder Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	144 %
Prated	35.00 kW	35.00 kW
SCOP	4.85	3.80
Tbiv	-18 °C	-16 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	31.00 kW	30.10 kW
COP Tj = -7°C	4.75	3.55
Pdh Tj = +2°C	15.60 kW	15.30 kW
COP Tj = +2°C	5.06	4.04
Pdh Tj = +7°C	15.60 kW	15.40 kW
COP Tj = +7°C	5.14	4.39
Pdh Tj = 12°C	15.60 kW	15.50 kW
COP Tj = 12°C	4.86	4.55
Pdh Tj = Tbiv	30.80 kW	29.60 kW
COP Tj = Tbiv	4.55	3.24

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	30.80 kW	19.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.38	2.99
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.98	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	60 W	60 W
PSB	7 W	7 W
PCK	70 W	70 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.20 kW	5.70 kW
Annual energy consumption Q_{he}	17817 kWh	22770 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	178 %	137 %
Prated	35.00 kW	35.00 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

SCOP	4.65	3.63
Tbiv	-7 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	30.80 kW	29.50 kW
COP Tj = -7°C	4.51	3.15
Pdh Tj = +2°C	30.90 kW	30.20 kW
COP Tj = +2°C	4.69	3.64
Pdh Tj = +7°C	15.60 kW	15.30 kW
COP Tj = +7°C	5.02	4.09
Pdh Tj = 12°C	15.60 kW	15.40 kW
COP Tj = 12°C	5.01	4.40
Pdh Tj = Tbiv	30.80 kW	29.60 kW
COP Tj = Tbiv	4.51	3.23
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	30.80 kW	29.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.38	2.99
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	80 W	80 W
PSB	7 W	7 W
PCK	70 W	70 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.20 kW	5.70 kW
Annual energy consumption Q _{he}	15539 kWh	19880 kWh