

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	NIMBUS 70 S-T - ARIANEXT 70 S-T - AEROTOP SPLIT 07		Reg. No.	ICIM-PDC-000001
Certificate Holder				
Name	Ariston Thermo Group			
Address	Viale Aristide Merloni 45		Zip	I-60044
City	Fabriano (AN)		Country	Italy
Certification Body	ICIM S.p.A.			
Subtype title	NIMBUS 70 S-T - ARIANEXT 70 S-T - AEROTOP SPLIT 07			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R410A			
Mass of Refrigerant	3.08 kg			
Certification Date	19.12.2017			

Model: AEROTOP SPLIT 07M-R

Configure model	
Model name	AEROTOP SPLIT 07M-R
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95

Warmer Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	4.85 kW	4.40 kW
η_s	233 %	153 %
P _{rated}	4.85 kW	4.40 kW
SCOP	5.90	3.90
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	4.85 kW	4.40 kW
COP T _j = +2°C	4.16	2.36
P _{dh} T _j = +7°C	3.26 kW	3.01 kW
COP T _j = +7°C	5.48	3.34
P _{dh} T _j = 12°C	2.72 kW	2.62 kW
COP T _j = 12°C	7.46	5.50
P _{dh} T _j = T _{biv}	4.85 kW	4.40 kW
COP T _j = T _{biv}	4.16	2.36

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	4.85 kW	4.40 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.16	2.36
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
$P_{designh}$	11.71 kW	11.02 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

η_s	151 %	118 %
Prated	11.71 kW	11.02 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW
COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.52 kW	4.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.23	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Q _{he}	7482 kWh	8977 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
P _{designh}	7.88 kW	7.68 kW
η _s	191 %	133 %
P _{rated}	7.88 kW	7.68 kW
SCOP	4.86	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	6.97 kW	6.80 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31
Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.70 kW	6.75 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Model: ARIANEXT PLUS 70 S-T LINK

Configure model	
Model name	ARIANEXT PLUS 70 S-T LINK
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95

Warmer Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
$P_{designh}$	4.85 kW	4.40 kW
η_s	233 %	153 %
P_{rated}	4.85 kW	4.40 kW
SCOP	5.90	3.90
T_{biv}	2 °C	2 °C
TOL	2 °C	2 °C
$P_{dh} T_j = +2^{\circ}C$	4.85 kW	4.40 kW
$COP T_j = +2^{\circ}C$	4.16	2.36
$P_{dh} T_j = +7^{\circ}C$	3.26 kW	3.01 kW
$COP T_j = +7^{\circ}C$	5.48	3.34
$P_{dh} T_j = 12^{\circ}C$	2.72 kW	2.62 kW
$COP T_j = 12^{\circ}C$	7.46	5.50
$P_{dh} T_j = T_{biv}$	4.85 kW	4.40 kW
$COP T_j = T_{biv}$	4.16	2.36

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	4.85 kW	4.40 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.16	2.36
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
$P_{designh}$	11.71 kW	11.02 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

η_s	151 %	118 %
Prated	11.71 kW	11.02 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW
COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.52 kW	4.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.23	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Q _{he}	7482 kWh	8977 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
P _{designh}	7.88 kW	7.68 kW
η _s	191 %	133 %
P _{rated}	7.88 kW	7.68 kW
SCOP	4.86	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	6.97 kW	6.80 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31
Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.70 kW	6.75 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Model: ARIANEXT PLUS 70 S-T

Configure model	
Model name	ARIANEXT PLUS 70 S-T
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95

Warmer Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	4.85 kW	4.40 kW
η_s	233 %	153 %
P _{rated}	4.85 kW	4.40 kW
SCOP	5.90	3.90
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	4.85 kW	4.40 kW
COP T _j = +2°C	4.16	2.36
P _{dh} T _j = +7°C	3.26 kW	3.01 kW
COP T _j = +7°C	5.48	3.34
P _{dh} T _j = 12°C	2.72 kW	2.62 kW
COP T _j = 12°C	7.46	5.50
P _{dh} T _j = T _{biv}	4.85 kW	4.40 kW
COP T _j = T _{biv}	4.16	2.36

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	4.85 kW	4.40 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.16	2.36
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
$P_{designh}$	11.71 kW	11.02 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

η_s	151 %	118 %
Prated	11.71 kW	11.02 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW
COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.52 kW	4.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.23	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Q _{he}	7482 kWh	8977 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
P _{designh}	7.88 kW	7.68 kW
η _s	191 %	133 %
P _{rated}	7.88 kW	7.68 kW
SCOP	4.86	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	6.97 kW	6.80 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31
Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.70 kW	6.75 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Model: NIMBUS PLUS 70 S-T NET

Configure model	
Model name	NIMBUS PLUS 70 S-T NET
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95

Warmer Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	4.85 kW	4.40 kW
η_s	233 %	153 %
P _{rated}	4.85 kW	4.40 kW
SCOP	5.90	3.90
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	4.85 kW	4.40 kW
COP T _j = +2°C	4.16	2.36
P _{dh} T _j = +7°C	3.26 kW	3.01 kW
COP T _j = +7°C	5.48	3.34
P _{dh} T _j = 12°C	2.72 kW	2.62 kW
COP T _j = 12°C	7.46	5.50
P _{dh} T _j = T _{biv}	4.85 kW	4.40 kW
COP T _j = T _{biv}	4.16	2.36

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	4.85 kW	4.40 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.16	2.36
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
$P_{designh}$	11.71 kW	11.02 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

η_s	151 %	118 %
Prated	11.71 kW	11.02 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW
COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.52 kW	4.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.23	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Q _{he}	7482 kWh	8977 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
P _{designh}	7.88 kW	7.68 kW
η _s	191 %	133 %
P _{rated}	7.88 kW	7.68 kW
SCOP	4.86	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	6.97 kW	6.80 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31
Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.70 kW	6.75 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Model: AEROTOP SPLIT 07M-CR

Configure model	
Model name	AEROTOP SPLIT 07M-CR
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95

Warmer Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	4.85 kW	4.40 kW
η_s	233 %	153 %
P _{rated}	4.85 kW	4.40 kW
SCOP	5.90	3.90
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	4.85 kW	4.40 kW
COP T _j = +2°C	4.16	2.36
P _{dh} T _j = +7°C	3.26 kW	3.01 kW
COP T _j = +7°C	5.48	3.34
P _{dh} T _j = 12°C	2.72 kW	2.62 kW
COP T _j = 12°C	7.46	5.50
P _{dh} T _j = T _{biv}	4.85 kW	4.40 kW
COP T _j = T _{biv}	4.16	2.36

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	4.85 kW	4.40 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.16	2.36
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
$P_{designh}$	11.71 kW	11.02 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

η_s	151 %	118 %
Prated	11.71 kW	11.02 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW
COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.52 kW	4.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.23	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Q _{he}	7482 kWh	8977 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
P _{designh}	7.88 kW	7.68 kW
η _s	191 %	133 %
P _{rated}	7.88 kW	7.68 kW
SCOP	4.86	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	6.97 kW	6.80 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31
Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.70 kW	6.75 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	118 %
COP	2.84
Heating up time	01:27 h:min
Standby power input	44.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	93 %
COP	2.25
Heating up time	01:22 h:min
Standby power input	54.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	244 l

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	108 %
COP	2.60
Heating up time	01:30 h:min
Standby power input	49.0 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	247 l

Model: NIMBUS COMPACT 70 S-T NET

Configure model	
Model name	NIMBUS COMPACT 70 S-T NET
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95

Warmer Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	4.85 kW	4.40 kW
η_s	233 %	153 %
P _{rated}	4.85 kW	4.40 kW
SCOP	5.90	3.90
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	4.85 kW	4.40 kW
COP T _j = +2°C	4.16	2.36
P _{dh} T _j = +7°C	3.26 kW	3.01 kW
COP T _j = +7°C	5.48	3.34
P _{dh} T _j = 12°C	2.72 kW	2.62 kW
COP T _j = 12°C	7.46	5.50
P _{dh} T _j = T _{biv}	4.85 kW	4.40 kW
COP T _j = T _{biv}	4.16	2.36

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	4.85 kW	4.40 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.16	2.36
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
$P_{designh}$	11.71 kW	11.02 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

η_s	151 %	118 %
Prated	11.71 kW	11.02 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW
COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.52 kW	4.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.23	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Q _{he}	7482 kWh	8977 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
P _{designh}	7.88 kW	7.68 kW
η _s	191 %	133 %
P _{rated}	7.88 kW	7.68 kW
SCOP	4.86	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	6.97 kW	6.80 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31
Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.70 kW	6.75 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	118 %
COP	2.84
Heating up time	01:27 h:min
Standby power input	44.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	93 %
COP	2.25
Heating up time	01:22 h:min
Standby power input	54.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	244 l

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	108 %
COP	2.60
Heating up time	01:30 h:min
Standby power input	49.0 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	247 l

Model: NIMBUS FLEX 70 S-T NET

Configure model	
Model name	NIMBUS FLEX 70 S-T NET
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.40 kW	5.78 kW
El input	1.28 kW	1.96 kW
COP	5.00	2.95

Warmer Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	4.85 kW	4.40 kW
η_s	233 %	153 %
P _{rated}	4.85 kW	4.40 kW
SCOP	5.90	3.90
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	4.85 kW	4.40 kW
COP T _j = +2°C	4.16	2.36
P _{dh} T _j = +7°C	3.26 kW	3.01 kW
COP T _j = +7°C	5.48	3.34
P _{dh} T _j = 12°C	2.72 kW	2.62 kW
COP T _j = 12°C	7.46	5.50
P _{dh} T _j = T _{biv}	4.85 kW	4.40 kW
COP T _j = T _{biv}	4.16	2.36

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	4.85 kW	4.40 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.16	2.36
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	1098 kWh	1507 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
$P_{designh}$	11.71 kW	11.02 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

η_s	151 %	118 %
Prated	11.71 kW	11.02 kW
SCOP	3.86	3.03
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.09 kW	6.67 kW
COP Tj = -7°C	3.42	2.67
Pdh Tj = +2°C	4.41 kW	4.04 kW
COP Tj = +2°C	5.27	3.88
Pdh Tj = +7°C	2.89 kW	2.66 kW
COP Tj = +7°C	6.51	5.10
Pdh Tj = 12°C	2.73 kW	2.69 kW
COP Tj = 12°C	8.04	6.78
Pdh Tj = Tbiv	7.09 kW	6.67 kW
COP Tj = Tbiv	3.42	2.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.52 kW	4.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.23	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.00 kW	4.00 kW
Annual energy consumption Q _{he}	7482 kWh	8977 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
P _{designh}	7.88 kW	7.68 kW
η _s	191 %	133 %
P _{rated}	7.88 kW	7.68 kW
SCOP	4.86	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	6.97 kW	6.80 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = -7°C	3.13	2.22
Pdh Tj = +2°C	4.35 kW	4.11 kW
COP Tj = +2°C	4.81	3.36
Pdh Tj = +7°C	2.87 kW	2.57 kW
COP Tj = +7°C	6.13	4.47
Pdh Tj = 12°C	2.73 kW	2.66 kW
COP Tj = 12°C	8.04	6.31
Pdh Tj = Tbiv	6.97 kW	6.80 kW
COP Tj = Tbiv	3.13	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.70 kW	6.75 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	11 W	11 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.18 kW	0.93 kW
Annual energy consumption Qhe	3352 kWh	4670 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	118 %
COP	2.84
Heating up time	01:27 h:min
Standby power input	44.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	93 %
COP	2.25
Heating up time	01:22 h:min
Standby power input	54.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	244 l

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	108 %
COP	2.60
Heating up time	01:30 h:min
Standby power input	49.0 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	247 l