

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	R32 monobloc(2nd) 12 14 16 kW 1&3 phase	Reg. No.	011-1W0470
Certificate Holder			
Name	LG Electronics Inc.		
Address	84, Wanam-ro, seongsan-gu	Zip	51554
City	Changwon-si	Country	South Korea
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	R32 monobloc(2nd) 12 14 16 kW 1&3 phase		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	2 kg		
Certification Date	05.07.2021		
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 9 (as of 2021-03)		

Model: HM121MR U34

Configure model

Model name	HM121MR U34
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	12.00 kW	11.00 kW
El input	2.45 kW	3.79 kW
COP	4.90	2.90

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	184 %	136 %
Prated	12.00 kW	12.00 kW
SCOP	4.67	3.47
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.20 kW	10.20 kW
COP Tj = -7°C	3.10	2.07
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.20 kW	6.30 kW
COP Tj = +2°C	4.39	3.38
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	6.40	4.64
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	5.20 kW	4.60 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP Tj = 12°C	8.50	6.79
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.50 kW	10.20 kW
COP Tj = Tbiv	2.55	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.50 kW	10.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.55	1.92
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	30 W	30 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	1.20 kW
Annual energy consumption Qhe	5086 kWh	6882 kWh

Model: HM123MR U34

Configure model

Model name	HM123MR U34
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	12.00 kW	11.00 kW
El input	2.45 kW	3.79 kW
COP	4.90	2.90

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	184 %	136 %
Prated	12.00 kW	12.00 kW
SCOP	4.67	3.47
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.20 kW	10.20 kW
COP Tj = -7°C	3.10	2.07
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.20 kW	6.30 kW
COP Tj = +2°C	4.39	3.38
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	6.40	4.64
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	5.20 kW	4.60 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP Tj = 12°C	8.50	6.79
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.50 kW	10.20 kW
COP Tj = Tbiv	2.55	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.50 kW	10.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.55	1.92
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	30 W	30 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	1.20 kW
Annual energy consumption Qhe	5086 kWh	6882 kWh

Model: HM141MR U34

Configure model

Model name	HM141MR U34
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	14.00 kW	11.50 kW
El input	2.92 kW	4.04 kW
COP	4.80	2.85

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	182 %	135 %
Prated	12.00 kW	12.00 kW
SCOP	4.62	3.46
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.60 kW	10.40 kW
COP Tj = -7°C	3.10	2.11
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.50 kW	6.30 kW
COP Tj = +2°C	4.40	3.35
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.60 kW	4.70 kW
COP Tj = +7°C	6.10	4.66
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	5.30 kW	4.60 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP Tj = 12°C	8.40	6.62
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	12.00 kW	10.40 kW
COP Tj = Tbiv	2.50	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	10.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	30 W	30 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	1.10 kW
Annual energy consumption Qhe	5362 kWh	7016 kWh

Model: HM143MR U34

Configure model

Model name	HM143MR U34
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	14.00 kW	11.50 kW
El input	2.92 kW	4.04 kW
COP	4.80	2.85

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	182 %	135 %
Prated	12.00 kW	12.00 kW
SCOP	4.62	3.46
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.60 kW	10.40 kW
COP Tj = -7°C	3.10	2.11
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.50 kW	6.30 kW
COP Tj = +2°C	4.40	3.35
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.60 kW	4.70 kW
COP Tj = +7°C	6.10	4.66
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	5.30 kW	4.60 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP Tj = 12°C	8.40	6.62
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	12.00 kW	10.40 kW
COP Tj = Tbiv	2.50	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	10.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	30 W	30 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	1.10 kW
Annual energy consumption Qhe	5362 kWh	7016 kWh

Model: HM163MR U34

Configure model

Model name	HM163MR U34
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	16.00 kW	12.00 kW
El input	3.40 kW	4.29 kW
COP	4.70	2.80

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	135 %
Prated	12.00 kW	12.00 kW
SCOP	4.53	3.45
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.90 kW	10.70 kW
COP Tj = -7°C	3.09	2.13
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.60 kW	6.50 kW
COP Tj = +2°C	4.33	3.34
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.00 kW	5.20 kW
COP Tj = +7°C	5.90	4.65
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	5.30 kW	4.60 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP Tj = 12°C	8.15	6.58
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	12.30 kW	10.60 kW
COP Tj = Tbiv	2.50	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.30 kW	11.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	30 W	30 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	5604 kWh	7213 kWh

Model: HM161MR U34

Configure model

Model name	HM161MR U34
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	16.00 kW	12.00 kW
El input	3.40 kW	4.29 kW
COP	4.70	2.80

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	135 %
Prated	12.00 kW	12.00 kW
SCOP	4.53	3.45
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.90 kW	10.70 kW
COP Tj = -7°C	3.09	2.13
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.60 kW	6.50 kW
COP Tj = +2°C	4.33	3.34
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.00 kW	5.20 kW
COP Tj = +7°C	5.90	4.65
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	5.30 kW	4.60 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP Tj = 12°C	8.15	6.58
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	12.30 kW	10.60 kW
COP Tj = Tbiv	2.50	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.30 kW	11.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	30 W	30 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	5604 kWh	7213 kWh