Login

Summary of	ADAPT 0312	Reg. No.	011-1W0516
Certificate Holder			
Name	KRONOTERM d.o.o.		
Address	Trnava 5e	Zip	3303
City	Gomilsko	Country	Slovenia
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	ADAPT 0312		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R452B		
Mass of Refrigerant	2.9 kg		
Certification Date	18.01.2022		
Testing basis	HP KEYMARK certification scheme rules rev. 9		

Model: ADAPT 0312-K3 HT / HK 1F

Configure model	
Model name	ADAPT 0312-K3 HT / HK 1F
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.08 kW	5.87 kW
El input	1.13 kW	1.91 kW
COP	5.45	3.08

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	44 dB(A)	42 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	194 %	139 %
Prated	8.10 kW	7.40 kW
SCOP	5.08	3.65
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.22 kW	6.37 kW
COP Tj = -7°C	3.35	2.43
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	4.60 kW	4.36 kW
COP Tj = +2°C	5.22	3.71
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.88 kW	2.78 kW
COP Tj = +7°C	6.13	4.45
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.77 kW	2.88 kW

COP Tj = 12°C	6.90	5.67
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.00 kW	7.40 kW
COP Tj = Tbiv	3.04	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.00 kW	7.41 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.04	2.01
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	67 °C	67 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.10 kW	0.00 kW
Annual energy consumption Qhe	3295 kWh	4192 kWh

Model: ADAPT 0312-K3 HT / HK 1F + HYDRO C

Configure model	
Model name	ADAPT 0312-K3 HT / HK 1F + HYDRO C
Application	Heating + DHW
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2	
	Medium temperature
Heat output	5.87 kW
El input	1.91 kW
COP	3.08

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1	
	Medium temperature
Sound power level indoor	0 dB(A)
Sound power level outdoor	42 dB(A)

EN 14825	
	Medium temperature
η_s	139 %
Prated	7.40 kW
SCOP	3.65
Tbiv	-10 °C
TOL	-10 °C
Pdh Tj = -7°C	6.37 kW
COP Tj = -7°C	2.43
Cdh Tj = -7 °C	0.900
Pdh Tj = +2°C	4.36 kW
COP Tj = +2°C	3.71
Cdh Tj = +2 °C	0.900
Pdh Tj = +7°C	2.78 kW
COP Tj = +7°C	4.45
Cdh Tj = +7 °C	0.900

Pdh Tj = 12°C	2.88 kW
COP Tj = 12°C	5.67
Cdh Tj = +12 °C	0.900
Pdh Tj = Tbiv	7.41 kW
COP Tj = Tbiv	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.41 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.01
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900
WTOL	67 °C
Poff	14 W
PTO	14 W
PSB	14 W
PCK	14 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	4192 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	116 %
COP	2.74
Heating up time	1:46 h:min
Standby power input	68.2 W
Reference hot water temperature	55.5 °C
Mixed water at 40°C	260 l

Model: ADAPT 0312-K3 HT / HK 3F

Configure model	
Model name	ADAPT 0312-K3 HT / HK 3F
Application	Heating (medium temp)
Units	Indoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.02 kW	5.87 kW
El input	1.12 kW	1.92 kW
COP	5.41	3.06

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	42 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	188 %	137 %
Prated	8.40 kW	7.80 kW
SCOP	4.93	3.57
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.30 kW	6.46 kW
COP Tj = -7°C	3.45	2.44
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	4.83 kW	4.48 kW
COP Tj = +2°C	4.87	3.72
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.04 kW	2.75 kW
COP Tj = +7°C	6.19	4.25
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.01 kW	2.92 kW

COP Tj = 12°C	7.19	5.36
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.05 kW	7.48 kW
COP Tj = Tbiv	3.11	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.05 kW	7.48 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.11	2.04
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	67 °C	67 °C
Poff	14 W	14 W
PTO	14 W	14 W
PSB	14 W	14 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.35 kW	0.32 kW
Annual energy consumption Qhe	3520 kWh	4510 kWh

Model: ADAPT 0312-K3 HT / HK 3F + HYDRO C

Configure model	
Model name	ADAPT 0312-K3 HT / HK 3F + HYDRO C
Application	Heating + DHW
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Average Climate

EN 12102-1	
	Medium temperature
Sound power level indoor	0 dB(A)
Sound power level outdoor	42 dB(A)

EN 14825	
	Medium temperature
η_s	137 %
Prated	7.80 kW
SCOP	3.57
Tbiv	-10 °C
TOL	-10 °C
Pdh Tj = -7°C	6.46 kW

COP Tj = -7°C	2.44
Cdh Tj = -7 °C	0.900
Pdh Tj = +2°C	4.48 kW
COP Tj = +2°C	3.72
Cdh Tj = +2 °C	0.900
Pdh Tj = +7°C	2.75 kW
COP Tj = +7°C	4.25
Cdh Tj = +7 °C	0.900
Pdh Tj = 12°C	2.92 kW
COP Tj = 12°C	5.36
Cdh Tj = +12 °C	0.900
Pdh Tj = Tbiv	7.48 kW
COP Tj = Tbiv	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.48 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.04
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900
WTOL	67 °C
Poff	14 W
PTO	14 W
PSB	14 W
PCK	14 W

Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.32 kW
Annual energy consumption Qhe	4510 kWh

Heating

EN 14511-2	
	Medium temperature
Heat output	5.87 kW
El input	1.92 kW
COP	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	115 %
COP	2.73
Heating up time	1:46 h:min
Standby power input	69.0 W
Reference hot water temperature	55.4 °C
Mixed water at 40°C	261 l