Login

Summary of	DAITSU SPLIT URBAN 14 18	Reg. No.	041-K010-08
Certificate Holder			
Name	Eurofred S.A.		
Address	Marqués de Sentmenat, 97	Zip	08029
City	Barcelona	Country	Spain
Certification Body	BRE Global Limited		
Subtype title	DAITSU SPLIT URBAN 14 18		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.1 kg		
Certification Date	08.03.2021		
Testing basis	Heat Pump Keymark Scheme Rules Rev 09		

Model: SPLIT URBAN AOWD 14

Configure model	
Model name	SPLIT URBAN AOWD 14
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.00 kW	3.60 kW
El input	0.77 kW	1.31 kW
COP	5.19	2.75

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	232 %	154 %
Prated	5.00 kW	4.00 kW
SCOP	5.87	3.92
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.80 kW	4.20 kW
COP Tj = +2°C	3.46	2.10
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	3.30 kW	2.60 kW
COP Tj = +7°C	5.57	3.40
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.90 kW	2.70 kW
COP Tj = 12°C	7.60	5.55
Cdh Tj = +12 °C	0.930	0.950

Pdh Tj = Tbiv	4.80 kW	4.20 kW
COP Tj = Tbiv	3.46	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.46	2.10
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W
PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1137 kWh	1365 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	**Medium temperature**
η_s	145 %	95 %
Prated	4.00 kW	3.00 kW
SCOP	3.70	2.45
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	2.40 kW	1.90 kW
COP Tj = -7°C	2.68	1.72
Cdh Tj = -7 °C	0.970	0.980
Pdh Tj = +2°C	2.30 kW	1.90 kW
COP Tj = +2°C	5.34	3.41
Cdh Tj = +2 °C	0.940	0.960
Pdh Tj = +7°C	2.70 kW	2.60 kW
COP Tj = +7°C	7.04	5.29
Cdh Tj = +7 °C	0.940	0.950
Pdh Tj = 12°C	2.60 kW	2.90 kW
COP Tj = 12°C	6.90	6.71
Cdh Tj = +12 °C	0.930	0.940
Pdh Tj = Tbiv	3.10 kW	2.70 kW
COP Tj = Tbiv	2.06	1.35
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.80 kW	2.30 kW

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.19	1.35
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W
PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.30 kW	0.70 kW
Annual energy consumption Qhe	2662 kWh	3015 kWh
Pdh Tj = -15°C (if TOL<-20°C)	3.10	2.70
COP Tj = -15°C (if TOL<-20°C)	2.03	1.35
Cdh Tj = -15 °C	0.980	0.990

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	**Medium temperature**
η_s	184 %	128 %
Prated	5.00 kW	5.00 kW
SCOP	4.67	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.60 kW	4.00 kW
COP Tj = -7°C	3.23	2.03
Cdh Tj = -7 °C	0.980	0.990
Pdh Tj = +2°C	2.90 kW	2.60 kW
COP Tj = +2°C	4.59	3.27
Cdh Tj = +2 °C	0.960	0.970
Pdh Tj = +7°C	2.60 kW	2.30 kW
COP Tj = +7°C	6.39	4.30
Cdh Tj = +7 °C	0.940	0.950
Pdh Tj = 12°C	2.80 kW	2.80 kW
COP Tj = 12°C	6.37	6.00
Cdh Tj = +12 °C	0.940	0.950
Pdh Tj = Tbiv	4.60 kW	4.00 kW
COP Tj = Tbiv	3.23	2.03
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.20 kW	3.80 kW

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.38
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W
PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	1.20 kW
Annual energy consumption Qhe	2216 kWh	3152 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	122 %
COP	2.92
Heating up time	3:39 h:min
Standby power input	31.9 W
Reference hot water temperature	53.0 °C
Mixed water at 40°C	228 l

Colder Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	91 %
COP	2.18
Heating up time	4:10 h:min
Standby power input	39.2 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	226 l

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	116 %
COP	2.76
Heating up time	3:54 h:min
Standby power input	34.8 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	226 l

Model: SPLIT URBAN AOWD 18

Configure model	
Model name	SPLIT URBAN AOWD 18
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.00 kW	5.61 kW
El input	1.23 kW	1.93 kW
COP	4.88	2.90

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	232 %	160 %
Prated	5.00 kW	5.00 kW
SCOP	5.87	4.07
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.20 kW	5.10 kW
COP Tj = +2°C	3.53	2.14
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	3.30 kW	3.30 kW
COP Tj = +7°C	5.57	3.49
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.90 kW	2.70 kW
COP Tj = 12°C	7.60	5.67
Cdh Tj = +12 °C	0.930	0.950

Pdh Tj = Tbiv	5.20 kW	5.10 kW
COP Tj = Tbiv	3.53	2.14
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	5.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.53	2.14
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W
PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1136 kWh	1643 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	**Medium temperature**
η_s	145 %	104 %
Prated	4.00 kW	4.00 kW
SCOP	3.70	2.67
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	2.60 kW	2.40 kW
COP Tj = -7°C	2.69	1.83
Cdh Tj = -7 °C	0.970	0.980
Pdh Tj = +2°C	2.30 kW	2.10 kW
COP Tj = +2°C	5.34	3.87
Cdh Tj = +2 °C	0.940	0.950
Pdh Tj = +7°C	2.70 kW	2.50 kW
COP Tj = +7°C	7.04	5.31
Cdh Tj = +7 °C	0.940	0.950
Pdh Tj = 12°C	2.60 kW	2.90 kW
COP Tj = 12°C	6.90	6.73
Cdh Tj = +12 °C	0.930	0.940
Pdh Tj = Tbiv	3.40 kW	3.10 kW
COP Tj = Tbiv	1.98	1.38
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.70 kW	2.30 kW

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.58	1.10
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W
PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.30 kW	1.70 kW
Annual energy consumption Qhe	2674 kWh	3701 kWh
Pdh Tj = -15°C (if TOL<-20°C)	3.40	3.10
COP Tj = -15°C (if TOL<-20°C)	1.98	1.38
Cdh Tj = -15 °C	0.990	0.990

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	**Medium temperature**
η_s	182 %	128 %
Prated	6.00 kW	5.00 kW
SCOP	4.62	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.30 kW	4.00 kW
COP Tj = -7°C	2.81	2.03
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.30 kW	2.60 kW
COP Tj = +2°C	4.68	3.27
Cdh Tj = +2 °C	0.960	0.970
Pdh Tj = +7°C	2.60 kW	2.30 kW
COP Tj = +7°C	6.47	4.30
Cdh Tj = +7 °C	0.940	0.950
Pdh Tj = 12°C	2.80 kW	2.80 kW
COP Tj = 12°C	6.39	6.00
Cdh Tj = +12 °C	0.940	0.950
Pdh Tj = Tbiv	5.30 kW	4.00 kW
COP Tj = Tbiv	2.81	2.03
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.20 kW	3.80 kW

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.38
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W
PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.80 kW	1.20 kW
Annual energy consumption Qhe	2685 kWh	3152 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	122 %
COP	2.92
Heating up time	3:39 h:min
Standby power input	31.9 W
Reference hot water temperature	53.0 °C
Mixed water at 40°C	228 l

Colder Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	91 %
COP	2.18
Heating up time	4:10 h:min
Standby power input	39.2 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	226 l

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	116 %
COP	2.76
Heating up time	3:54 h:min
Standby power input	34.8 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	226 l