

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	AIM14	Reg. No.	ICIM-PDC-000015-01
Certificate Holder			
Name	Argoclima S.p.A		
Address	Via Alfeno Varo, 35	Zip	25020
City	Alfianello (BS)	Country	Italy
Certification Body	ICIM S.p.A.		
Subtype title	AIM14		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	3.1 kg		
Certification Date	10.10.2018		

Model: AIM14EMX3PH

Configure model	
Model name	AIM14EMX3PH
Application	Heating + DHW + low temp
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.57 kW	10.26 kW
El input	3.35 kW	4.83 kW
COP	4.06	2.13

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	70 dB(A)	70 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	153 %	111 %
Prated	9.83 kW	9.52 kW
SCOP	3.91	2.84
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.70 kW	8.42 kW
COP Tj = -7°C	2.49	1.58
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	4.95 kW	5.09 kW
COP Tj = +2°C	3.72	2.83
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.17 kW	3.53 kW
COP Tj = +7°C	5.53	3.87
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.86 kW	4.57 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	6.64	6.01
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.70 kW	8.42 kW
COP Tj = Tbiv	2.49	1.58
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.96 kW	6.81 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.24	1.19
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	5 W	5 W
PTO	8 W	8 W
PSB	5 W	5 W
PCK	35 W	35 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.88 kW	2.72 kW
Annual energy consumption Qhe	5194 kWh	6931 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	XL
Mixed water at 40°C	377 l
Efficiency η_{DHW}	85 %
COP	2.05
Heating up time	2:40 h:min
Standby power input	47.0 W
Reference hot water temperature	47.0 °C

Model: AIM14EMX

Configure model	
Model name	AIM14EMX
Application	Heating + DHW + low temp
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.57 kW	10.26 kW
El input	3.35 kW	4.83 kW
COP	4.06	2.13

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	70 dB(A)	70 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	153 %	111 %
Prated	9.83 kW	9.52 kW
SCOP	3.91	2.84
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.70 kW	8.42 kW
COP Tj = -7°C	2.49	1.58
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	4.95 kW	5.09 kW
COP Tj = +2°C	3.72	2.83
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.17 kW	3.53 kW
COP Tj = +7°C	5.53	3.87
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.86 kW	4.57 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	6.64	6.01
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.70 kW	8.42 kW
COP Tj = Tbiv	2.49	1.58
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.96 kW	6.81 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.24	1.19
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	5 W	5 W
PTO	8 W	8 W
PSB	5 W	5 W
PCK	35 W	35 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.88 kW	2.72 kW
Annual energy consumption Qhe	5194 kWh	6931 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Mixed water at 40°C	377 l
Efficiency η_{DHW}	85 %
COP	2.05
Heating up time	2:40 h:min
Standby power input	47.0 W
Reference hot water temperature	47.0 °C