

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	S2125-12	Reg. No.	012-C700115
Certificate Holder			
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Subtype title	S2125-12		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R290		
Mass of Refrigerant	0.8 kg		
Certification Date	30.12.2021		
Testing basis	EN 14511:2018, EN 14825:2018, EN 12102:2017		

Model: S2125-12 3x400V

Configure model	
Model name	S2125-12 3x400V
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.36 kW	7.91 kW
El input	1.25 kW	2.44 kW
COP	5.10	3.25

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	49 dB(A)	49 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	195 %	150 %
Prated	6.80 kW	7.60 kW
SCOP	4.96	3.83
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.47 kW	6.73 kW
COP Tj = -7°C	2.86	2.17
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	3.64 kW	4.18 kW
COP Tj = +2°C	5.03	3.83
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.44 kW	2.68 kW
COP Tj = +7°C	6.49	5.12
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	2.47 kW	2.40 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	7.36	5.87
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.63 kW	7.60 kW
COP Tj = Tbiv	2.51	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.63 kW	7.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	2.11
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	65 °C	65 °C
Poff	8 W	8 W
PTO	13 W	13 W
PSB	11 W	11 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2835 kWh	4102 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	49 dB(A)	49 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	Low temperature	Medium temperature
η_s	163 %	131 %
Prated	8.40 kW	8.40 kW
SCOP	4.15	3.35
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.04 kW	4.98 kW
COP Tj = -7°C	3.08	2.53
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.11 kW	3.18 kW
COP Tj = +2°C	5.40	4.25
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.24 kW	2.19 kW
COP Tj = +7°C	6.65	5.31
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.47 kW	2.41 kW
COP Tj = 12°C	7.36	6.06
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.87 kW	6.81 kW
COP Tj = Tbiv	2.61	2.13

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.67 kW	5.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.68
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	65 °C	65 °C
Poff	8 W	8 W
PTO	13 W	13 W
PSB	11 W	11 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	2.70 kW	2.80 kW
Annual energy consumption Qhe	4990 kWh	6189 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.87	6.81
COP Tj = -15°C (if TOL<-20°C)	2.61	2.13
Cdh Tj = -15 °C	1.000	1.000

Model: S2125-12 1x230V

Configure model	
Model name	S2125-12 1x230V
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.36 kW	7.91 kW
El input	1.25 kW	2.44 kW
COP	5.10	3.25

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	49 dB(A)	49 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	195 %	150 %
Prated	6.80 kW	7.60 kW
SCOP	4.96	3.83
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.47 kW	6.73 kW
COP Tj = -7°C	2.86	2.17
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	3.64 kW	4.18 kW
COP Tj = +2°C	5.03	3.83
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.44 kW	2.68 kW
COP Tj = +7°C	6.49	5.12
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	2.47 kW	2.40 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	7.36	5.87
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.63 kW	7.60 kW
COP Tj = Tbiv	2.51	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.63 kW	7.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	2.11
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	65 °C	65 °C
Poff	8 W	8 W
PTO	13 W	13 W
PSB	11 W	11 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2835 kWh	4102 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	49 dB(A)	49 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	Low temperature	Medium temperature
η_s	163 %	131 %
Prated	8.40 kW	8.40 kW
SCOP	4.15	3.35
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.04 kW	4.98 kW
COP Tj = -7°C	3.08	2.53
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.11 kW	3.18 kW
COP Tj = +2°C	5.40	4.25
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	2.24 kW	2.19 kW
COP Tj = +7°C	6.65	5.31
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.47 kW	2.41 kW
COP Tj = 12°C	7.36	6.06
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.87 kW	6.81 kW
COP Tj = Tbiv	2.61	2.13

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.67 kW	5.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	1.68
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	65 °C	65 °C
Poff	8 W	8 W
PTO	13 W	13 W
PSB	11 W	11 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	2.70 kW	2.80 kW
Annual energy consumption Qhe	4990 kWh	6189 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.87	6.81
COP Tj = -15°C (if TOL<-20°C)	2.61	2.13
Cdh Tj = -15 °C	1.000	1.000