

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	Volan 7	Reg. No.	011-1W0530
Certificate Holder			
Name	THERMAGEN sp. z o.o.		
Address	Ul. Warszawska 50	Zip	82-100
City	Nowy Dwór Gdański	Country	Poland
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Volan 7		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R290		
Mass of Refrigerant	0.75 kg		
Certification Date	01.06.2022		
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 9 (as of 2021-03)		

Model: Volan 7

Configure model	
Model name	Volan 7
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.30 kW	2.80 kW
El input	0.64 kW	0.85 kW
COP	5.20	3.30

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	202 %	159 %
Prated	4.00 kW	3.60 kW
SCOP	5.11	4.04
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.02 kW	3.63 kW
COP Tj = +2°C	3.00	2.11
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	2.54 kW	2.41 kW
COP Tj = +7°C	6.15	3.79
Cdh Tj = +7 °C	0.98	0.99
Pdh Tj = 12°C	1.23 kW	1.51 kW
COP Tj = 12°C	5.26	5.26
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	4.02 kW	3.63 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP $T_j = T_{biv}$	3.00	2.11
P _{dh} $T_j = TOL$ or P _{dh} $T_j = T_{designh}$ if $TOL < T_{designh}$	4.02 kW	3.63 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	3.00	2.11
WTOL	75 °C	75 °C
P _{off}	0 W	0 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	1045 kWh	1191 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	146 %	120 %
Prated	4.50 kW	4.30 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

SCOP	3.72	3.07
Tbiv	-12 °C	-12 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	2.73 kW	2.64 kW
COP Tj = -7°C	3.69	2.79
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	1.64 kW	1.57 kW
COP Tj = +2°C	4.95	3.87
Cdh Tj = +2 °C	0.970	0.980
Pdh Tj = +7°C	1.10 kW	1.27 kW
COP Tj = +7°C	4.73	4.64
Cdh Tj = +7 °C	0.960	0.960
Pdh Tj = 12°C	1.25 kW	1.20 kW
COP Tj = 12°C	5.47	5.02
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	3.29 kW	3.07 kW
COP Tj = Tbiv	3.17	2.47
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.32 kW	3.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.09	2.40
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	75 °C	75 °C

This information was generated by the HP KEYMARK database on 23 Jun 2022

Poff	0 W	0 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.50 kW	4.30 kW
Annual energy consumption Q _{he}	2983 kWh	3458 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	3.32	3.09
COP T _j = -15°C (if TOL<-20°C)	3.09	2.40
C _{dh} T _j = -15 °C	1.000	0.990

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	175 %	135 %
Prated	4.10 kW	4.00 kW
SCOP	4.45	3.45

This information was generated by the HP KEYMARK database on 23 Jun 2022

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.69 kW	3.47 kW
COP Tj = -7°C	2.96	2.21
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	2.26 kW	2.18 kW
COP Tj = +2°C	4.63	3.46
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	1.50 kW	1.37 kW
COP Tj = +7°C	5.61	4.46
Cdh Tj = +7 °C	0.97	0.97
Pdh Tj = 12°C	1.34 kW	1.45 kW
COP Tj = 12°C	5.79	5.57
Cdh Tj = +12 °C	0.96	0.96
Pdh Tj = Tbiv	3.69 kW	3.47 kW
COP Tj = Tbiv	2.96	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.63 kW	3.34 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.83	2.07
WTOL	75 °C	75 °C
Poff	0 W	0 W
PTO	10 W	10 W

This information was generated by the HP KEYMARK database on 23 Jun 2022

PSB	8 W	8 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.47 kW	0.66 kW
Annual energy consumption Q _{he}	1902 kWh	2396 kWh