

Page 1 of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Bosch Compress 7000 LW 80	Reg. No.	011-1W0159
Certificate Holder			
Name	Bosch Thermotechnik GmbH		
Address	Junkersstraße 20 - 24	Zip	73249
City	Wernau	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	RISE Research Institutes of Sweden AB		
Subtype title	Bosch Compress 7000 LW 80		
Heat Pump Type	Brine/Water		
Refrigerant	R410a		
Mass Of Refrigerant	10.8 kg		



This information was generated by the HP KEYMARK database on 17 Dec 2020

Model: Bosch Compress 7000 LW 80

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	78.16 kW	81.17 kW
El input	18.17 kW	26.65 kW
СОР	4.30	3.05
Indoor water flow rate	13.46 m³/h	8.74 m³/h

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	

Average Climate



This information was generated by the HP KEYMARK database on 17 Dec 2020

	EN 12102-1		
	Low temperature	Medium temperature	
Sound power level indoor	67 dB(A)	67 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	196 %	157 %
Prated	78.00 kW	78.00 kW
SCOP	5.10	4.12
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	69.00 kW	69.00 kW
COP Tj = -7°C	4.48	3.31
Pdh Tj = +2°C	42.02 kW	42.24 kW
COP Tj = +2°C	5.19	4.20
Pdh Tj = +7°C	41.93 kW	42.28 kW
COP Tj = +7°C	5.32	4.47
Pdh Tj = 12°C	41.86 kW	42.33 kW
COP Tj = 12°C	5.42	4.73
Pdh Tj = Tbiv	78.16 kW	81.17 kW
COP Tj = Tbiv	4.30	3.05

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}4 of 4$ This information was generated by the HP KEYMARK database on 17 Dec 2020$

Pdh Tj = TOL	78.16 kW	81.17 kW
COP Tj = TOL	4.30	3.05
Cdh	1.00	1.00
WTOL	68 °C	68 °C
Poff	25 W	25 W
РТО	25 W	25 W
PSB	25 W	25 W
PCK	0 W	o w
Supplementary Heater: Type of energy input	Electric	Electric
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	31613 kWh	39068 kWh