This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Ecodan Power Inverter 10-300D AA	Reg. No.	037-0015-20
Certificate Holder			
Name	Mitsubishi Electric Air Conditioning Systems Europe LTD		
Address	Nettlehill Road, Houston Industrial Estate	Zip	EH54 5EQ
City	Livingston	Country	United Kingdom
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Name of testing laboratory	Heat Pump Test Center WPZ, Switzerland		
Subtype title	Ecodan Power Inverter 10-300D AA		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	4.2 kg		
Certification Date	14.02.2020		
Testing basis	HP Keymark scheme rules rev. no. 6		

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: PUHZ-SW100VAA + EHST30C-M*D

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m³/h	1.20 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	9.55 kW	9.55 kW
COP Tj = TOL	1.80	1.80
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	XL
Efficiency ηDHW	120 %
COP	2.90
Heating up time	03:41 h:min
Standby power input	41.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: PUHZ-SW100VAA + EHST30C-YM*D

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m³/h	1.20 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	167 %	130 %
Prated	10.60 kW	10.00 kW
SCOP	4.25	3.33
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	9.55 kW	9.55 kW
COP Tj = TOL	1.80	1.80
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147	
Declared load profile	XL
Efficiency ηDHW	120 %
COP	2.90
Heating up time	03:41 h:min
Standby power input	41.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: PUHZ-SW100VAA + ERST30C-VM*D

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m³/h	1.20 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	170 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.32	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	9.55 kW	9.55 kW
COP Tj = TOL	1.80	1.80
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5026 kWh	6089 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147	
Declared load profile	XL
Efficiency ηDHW	120 %
COP	2.90
Heating up time	03:41 h:min
Standby power input	41.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: PUHZ-SW100YAA + EHST30C-M*D

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m³/h	1.20 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	9.55 kW	9.55 kW
COP Tj = TOL	1.80	1.80
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147	
Declared load profile	XL
Efficiency ηDHW	120 %
COP	2.90
Heating up time	03:41 h:min
Standby power input	41.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: PUHZ-SW100YAA + EHST30C-YM*D

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m³/h	1.20 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	165 %	129 %
Prated	10.60 kW	10.00 kW
SCOP	4.21	3.30
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	9.55 kW	9.55 kW
COP Tj = TOL	1.80	1.80
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	XL
Efficiency ηDHW	120 %
COP	2.90
Heating up time	03:41 h:min
Standby power input	41.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: PUHZ-SW100YAA + ERST30C-VM*D

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.20 kW	11.20 kW
El input	2.51 kW	4.13 kW
COP	4.46	2.71
Indoor water flow rate	1.93 m³/h	1.20 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	169 %	132 %
Prated	10.60 kW	10.00 kW
SCOP	4.31	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.40 kW	8.90 kW
COP Tj = -7°C	2.75	1.95
Cdh	1.00	1.00
Pdh Tj = +2°C	5.70 kW	5.40 kW
COP Tj = +2°C	4.21	3.22
Cdh	0.99	0.99
Pdh Tj = +7°C	4.50 kW	4.70 kW
COP Tj = +7°C	5.55	4.79
Cdh	0.98	0.99

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	4.30 kW	5.30 kW
COP Tj = 12°C	7.47	6.12
Cdh	0.97	0.98
Pdh Tj = Tbiv	9.40 kW	8.90 kW
COP Tj = Tbiv	2.75	1.95
Pdh Tj = TOL	9.55 kW	9.55 kW
COP Tj = TOL	1.80	1.80
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.40 kW
Annual energy consumption Qhe	5035 kWh	6101 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	XL
Efficiency ηDHW	120 %
COP	2.90
Heating up time	03:41 h:min
Standby power input	41.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.