

Page 1 of 13

#### This information was generated by the HP KEYMARK database on 7 Jul 2022

#### **Login**

Summary of	AQUATOP S06	Reg. No.	011-1W0304	
Certificate Holder		<u> </u>		
Name	ELCO GmbH			
Address	Hohenzollernstrasse 31	Zip	72379	
City	Hechingen	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für Ko	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	AQUATOP S06			
Heat Pump Type	Brine/Water and Water/Water			
Refrigerant	R410A			
Mass of Refrigerant	1.9 kg			
Certification Date	04.05.2019			



# **Model: AQUATOP S06**

Configure model		
Model name	AQUATOP S06	
Application	Heating (medium temp)	
Units	Indoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x230V 50Hz	

Brine/Water Heat Pump

## Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.59 kW	4.85 kW
El input	1.22 kW	1.86 kW
СОР	4.58	2.61

### Warmer Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825			
	Low temperature	Medium temperature	
$\eta_{s}$	191 %	137 %	
Prated	6.00 kW	5.00 kW	
SCOP	4.97	3.63	
Tbiv	2 °C	2 °C	
TOL	-22 °C	-22 °C	
Pdh Tj = +2°C	5.79 kW	5.25 kW	
$COP Tj = +2^{\circ}C$	4.39	2.57	
Pdh Tj = $+7^{\circ}$ C	5.90 kW	5.51 kW	
$COPTj = +7^{\circ}C$	5.53	3.26	
Pdh Tj = 12°C	6.07 kW	5.88 kW	
COP Tj = 12°C	5.53	4.48	
Pdh Tj = Tbiv	5.79 kW	5.25 kW	
COP Tj = Tbiv	4.39	2.59	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL $<$ Tdesignh	5.79 kW	5.25 kW	
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.39	2.59	





Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	o w	0 W
РТО	20 W	20 W
PSB	20 W	20 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	1556 kWh	1931 kWh

### Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	195 %	142 %
Prated	6.00 kW	5.00 kW
SCOP	5.08	3.75
Tbiv	-22 °C	-22 °C





mis information was gen	erated by the fir KETI	TANK database off 7 Jul 2022
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.40 kW	5.56 kW
COP Tj = -7°C	5.00	3.44
Pdh Tj = $+2$ °C	5.46 kW	5.77 kW
COP Tj = +2°C	5.39	4.16
Pdh Tj = $+7^{\circ}$ C	5.51 kW	5.93 kW
$COP Tj = +7^{\circ}C$	5.66	4.76
Pdh Tj = 12°C	5.56 kW	6.03 kW
COP Tj = 12°C	5.79	5.25
Pdh Tj = Tbiv	5.79 kW	5.25 kW
COP Tj = Tbiv	4.39	2.59
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.79 kW	5.25 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.39	2.59
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL $<$ Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W
РТО	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
	<del></del>	



|--|

# Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{S}$	189 %	137 %
Prated	6.00 kW	5.00 kW
SCOP	4.93	3.64
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.84 kW	5.35 kW
COP Tj = -7°C	4.47	2.79
Pdh Tj = $+2$ °C	5.96 kW	5.61 kW
COP Tj = +2°C	5.00	3.65
Pdh Tj = $+7^{\circ}$ C	6.02 kW	5.77 kW
COP Tj = +7°C	5.39	4.27
Pdh Tj = 12°C	6.13 kW	5.98 kW





COP Tj = 12°C	5.79	5.02
Pdh Tj = Tbiv	5.79 kW	5.25 kW
COP Tj = Tbiv	4.39	2.59
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.79 kW	5.25 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.39	2.59
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W
РТО	20 W	20 W
PSB	20 W	20 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	2426 kWh	2983 kWh

Water/Water Heat Pump

# Heating



EN 14511-4		
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	

EN 14511-2			
Low temperature Medium temperature			
Heat output	6.67 kW	6.07 kW	
El input	1.19 kW	1.79 kW	
СОР	5.61	3.39	

## Warmer Climate


EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{S}$	245 %	182 %
Prated	7.00 kW	6.00 kW





3	•	
SCOP	6.32	4.74
Tbiv	2 °C	2 °C
TOL	-22 °C	-22 °C
Pdh Tj = $+2$ °C	6.67 kW	6.07 kW
COP Tj = +2°C	5.61	3.39
Pdh Tj = $+7^{\circ}$ C	6.80 kW	6.37 kW
$COPTj = +7^{\circ}C$	6.22	4.27
Pdh Tj = 12°C	6.99 kW	6.80 kW
COP Tj = 12°C	7.07	5.86
Pdh Tj = Tbiv	6.67 kW	6.07 kW
COP Tj = Tbiv	5.61	3.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.67 kW	6.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.61	3.39
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	o w	0 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW





Annual energy consumption Qhe 1409 kWh 1711 kWh	
-------------------------------------------------	--

## Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	250 %	188 %
Prated	7.00 kW	6.00 kW
SCOP	6.46	4.89
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	6.22 kW	6.43 kW
COP Tj = -7°C	6.39	4.50
Pdh Tj = +2°C	4.29 kW	6.67 kW
COP Tj = +2°C	6.89	5.44
Pdh Tj = +7°C	6.35 kW	6.86 kW
COP Tj = +7°C	7.23	6.23
Pdh Tj = 12°C	6.41 kW	6.97 kW
	,	·




COP Tj = 12°C	7.40	6.87
Pdh Tj = Tbiv	6.67 kW	6.07 kW
COP Tj = Tbiv	5.61	3.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.67 kW	6.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.61	3.39
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W
РТО	20 W	20 W
PSB	20 W	20 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	2544 kWh	3059 kWh

## Average Climate

EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	39 dB(A)	39 dB(A)		

#### EN 14825





	Low temperature	Medium temperature
$\eta_{S}$	243 %	182 %
Prated	7.00 kW	6.00 kW
SCOP	6.28	6.00
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	6.73 kW	6.19 kW
COP Tj = $-7^{\circ}$ C	5.71	3.65
Pdh Tj = $+2$ °C	6.87 kW	6.49 kW
COP Tj = +2°C	6.39	4.78
Pdh Tj = $+7^{\circ}$ C	6.93 kW	6.67 kW
$COP Tj = +7^{\circ}C$	6.89	5.59
Pdh Tj = 12°C	7.06 kW	6.91 kW
COP Tj = 12°C	7.40	6.57
Pdh Tj = Tbiv	6.67 kW	6.07 kW
COP Tj = Tbiv	5.61	3.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.67 kW	6.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.61	3.39
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	o w



Page 13 of 13

PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	2193 kWh	2645 kWh