

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	Hi-Therma Split 8kW	Reg. No.	041-K021-02
Certificate Holder			
Name	Qingdao Hisense Hitachi Air-conditioning Systems Co.,Ltd.		
Address	Qianwangang Road	Zip	266555
City	Qingdao, Shandong	Country	China
Certification Body	BRE Global Limited		
Subtype title	Hi-Therma Split 8kW		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.26 kg		
Certification Date	22.11.2021		
Testing basis	Heat Pump Keymark Scheme Rules Rev 08		

Model: AHW-080HCDS1+AHM-080HCDSAA

Configure model	
Model name	AHW-080HCDS1+AHM-080HCDSAA
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	8.14 kW	8.06 kW
El input	1.64 kW	2.79 kW
COP	4.96	2.89

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	194 %	134 %
Prated	6.54 kW	5.88 kW
SCOP	4.92	3.42
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.76 kW	5.17 kW
COP Tj = -7°C	3.14	1.85
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.52 kW	3.16 kW
COP Tj = +2°C	4.84	3.40
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.32 kW	2.15 kW
COP Tj = +7°C	5.98	4.50
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	1.98 kW	2.14 kW
COP Tj = 12°C	9.67	7.71
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.76 kW	5.17 kW
COP Tj = Tbiv	3.14	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.16 kW	5.67 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.66	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	10 W	10 W
PTO	11 W	11 W
PSB	10 W	10 W
PCK	1 W	1 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.37 kW	0.20 kW
Annual energy consumption Qhe	2732 kWh	3536 kWh