

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	NIBE AMS 10-16	Reg. No.	012-SC0606-18
Certificate Holder			
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Subtype title	NIBE AMS 10-16		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	4 kg		
Certification Date	20.09.2018		

Model: NIBE AMS 10-16 + HBS05-16

Configure model	
Model name	NIBE AMS 10-16 + HBS05-16
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.03 kW	6.38 kW
El input	1.45 kW	2.04 kW
COP	4.85	3.13

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	134 %
Prated	14.50 kW	14.00 kW
SCOP	4.47	3.42
Tbiv	-8 °C	-8 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.90 kW	12.50 kW
COP Tj = -7°C	2.96	2.01
Pdh Tj = +2°C	7.90 kW	7.60 kW
COP Tj = +2°C	4.37	3.29
Pdh Tj = +7°C	5.10 kW	4.90 kW
COP Tj = +7°C	5.58	4.68
Pdh Tj = 12°C	6.40 kW	6.80 kW
COP Tj = 12°C	6.99	6.51
Pdh Tj = Tbiv	13.40 kW	12.70 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.86	1.95
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	12.50 kW	11.00 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.71	1.95
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.97	0.98
WTOL	65 °C	65 °C
P _{off}	2 W	2 W
PTO	25 W	16 W
PSB	15 W	15 W
PCK	35 W	35 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.00 kW	3.00 kW
Annual energy consumption Q_{he}	6702 kWh	8431 kWh

Model: NIBE AMS 10-16 + SHB10-16

Configure model	
Model name	NIBE AMS 10-16 + SHB10-16
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.03 kW	6.38 kW
El input	1.45 kW	2.04 kW
COP	4.85	3.13

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	134 %
Prated	14.50 kW	14.00 kW
SCOP	4.47	3.42
Tbiv	-8 °C	-8 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.90 kW	12.50 kW
COP Tj = -7°C	2.96	2.01
Cdh Tj = -7 °C	0.98	0.98
Pdh Tj = +2°C	7.90 kW	7.60 kW
COP Tj = +2°C	4.37	3.29
Cdh Tj = +2 °C	0.98	0.98
Pdh Tj = +7°C	5.10 kW	4.90 kW
COP Tj = +7°C	5.58	4.68
Cdh Tj = +7 °C	0.98	0.98

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	6.40 kW	6.80 kW
COP Tj = 12°C	6.99	6.51
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	13.40 kW	12.70 kW
COP Tj = Tbiv	2.86	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	11.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.95
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	25 W	25 W
PSB	15 W	15 W
PCK	35 W	35 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.00 kW	3.00 kW
Annual energy consumption Qhe	6702 kWh	8431 kWh