

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Bosch Compress 7000 LW 72	Reg. No.	011-1W0158
Certificate Holder			
Name	Bosch Thermotechnik GmbH		
Address	Junkersstraße 20 - 24	Zip	73249
City	Wernau	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	RISE Research Institutes of Sweden AB		
Subtype title	Bosch Compress 7000 LW 72		
Heat Pump Type	Brine/Water		
Refrigerant	R410a		
Mass Of Refrigerant	10.6 kg		

## Model: Bosch Compress 7000 LW 72

### General Data

Power supply	3x400V 50Hz
--------------	-------------

### Heating

#### EN 14511-2

	Low temperature	Medium temperature
Heat output	72.98 kW	73.74 kW
El input	16.63 kW	24.70 kW
COP	4.39	2.99
Indoor water flow rate	12.57 m <sup>3</sup> /h	7.94 m <sup>3</sup> /h

#### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

### Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	67 dB(A)	67 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	197 %	157 %
Prated	70.00 kW	71.00 kW
SCOP	5.13	4.13
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	61.92 kW	62.81 kW
COP Tj = -7°C	4.57	3.27
Pdh Tj = +2°C	38.01 kW	38.36 kW
COP Tj = +2°C	5.21	4.22
Pdh Tj = +7°C	37.94 kW	38.23 kW
COP Tj = +7°C	5.34	4.51
Pdh Tj = 12°C	37.88 kW	38.11 kW
COP Tj = 12°C	5.45	4.77
Pdh Tj = Tbiv	72.98 kW	73.74 kW
COP Tj = Tbiv	4.39	2.99

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	72.98 kW	73.74 kW
COP Tj = TOL	4.39	2.99
Cdh	1.00	1.00
WTOL	68 °C	68 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electric	Electric
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	28185 kWh	35478 kWh