Login

Summary of	WPE-I 12/15 H(K)(W) 230 (GB) Premium	Reg. No.	011-1W0395
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPE-I 12/15 H(K)(W) 230 (GB) Premium		
Heat Pump Type	Brine/Water		
Refrigerant	R454C		
Mass of Refrigerant	3.1 kg		
Certification Date	08.09.2020		

Model: WPE-I 12 H(K)(W) 230 Premium

Configure model	
Model name	WPE-I 12 H(K)(W) 230 Premium
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.19 kW	4.20 kW
El input	0.84 kW	1.34 kW
COP	5.01	3.13

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	216 %	169 %
Prated	12.03 kW	11.99 kW
SCOP	5.59	4.42
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.61 kW	10.59 kW
COP Tj = -7°C	4.81	3.55
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.45 kW	6.44 kW
COP Tj = +2°C	5.72	4.49
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.14 kW	4.13 kW
COP Tj = +7°C	6.12	4.99
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.30 kW	2.21 kW

COP Tj = 12°C	6.29	5.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.03 kW	11.99 kW
COP Tj = Tbiv	4.53	3.29
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.03 kW	11.99 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.53	3.29
WTOL	75 °C	75 °C
Poff	19 W	19 W
PTO	19 W	19 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4445 kWh	5607 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

η_s	214 %	168 %
Prated	12.03 kW	11.99 kW
SCOP	5.55	4.39
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	12.03 kW	11.99 kW
COP Tj = +2°C	4.53	3.29
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	7.71 kW	7.69 kW
COP Tj = +7°C	5.51	4.12
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.41 kW	3.41 kW
COP Tj = 12°C	6.14	5.10
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.03 kW	11.99 kW
COP Tj = Tbiv	4.53	3.29
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.03 kW	11.99 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.53	3.29
WTOL	75 °C	75 °C
Poff	19 W	19 W

PTO	19 W	19 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2896 kWh	3650 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	224 %	174 %
Prated	12.03 kW	11.99 kW
SCOP	5.80	4.56
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.26 kW	7.24 kW
COP Tj = -7°C	5.69	4.31

Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.41 kW	4.40 kW
COP Tj = +2°C	6.16	4.91
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.82 kW	2.82 kW
COP Tj = +7°C	6.19	5.16
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.29 kW	2.23 kW
COP Tj = 12°C	6.12	5.40
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.03 kW	11.99 kW
COP Tj = Tbiv	4.53	3.29
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.03 kW	11.99 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.53	3.29
WTOL	75 °C	75 °C
Poff	19 W	19 W
PTO	19 W	19 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	5108 kWh	6485 kWh

Model: WPE-I 15 H(K)(W) 230 Premium

Configure model	
Model name	WPE-I 15 H(K)(W) 230 Premium
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	5.18 kW	4.72 kW
El input	1.07 kW	1.48 kW
COP	4.86	3.18

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	210 %	168 %
Prated	14.46 kW	13.77 kW
SCOP	5.44	4.39
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.77 kW	12.16 kW
COP Tj = -7°C	4.46	3.40
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	7.76 kW	7.40 kW
COP Tj = +2°C	5.51	4.44
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.98 kW	4.75 kW
COP Tj = +7°C	6.13	5.03
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.29 kW	2.22 kW

COP Tj = 12°C	6.18	5.31
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.46 kW	13.77 kW
COP Tj = Tbiv	4.30	3.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.46 kW	13.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.30	3.26
WTOL	75 °C	75 °C
Poff	19 W	19 W
PTO	19 W	19 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5489 kWh	6476 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

η_s	208 %	167 %
Prated	14.46 kW	13.77 kW
SCOP	5.41	4.37
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	14.46 kW	13.77 kW
COP Tj = +2°C	4.30	3.26
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	9.27 kW	8.83 kW
COP Tj = +7°C	5.13	3.99
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.11 kW	3.92 kW
COP Tj = 12°C	6.17	5.16
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.46 kW	13.77 kW
COP Tj = Tbiv	4.30	3.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.46 kW	13.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.30	3.26
WTOL	75 °C	75 °C
Poff	19 W	19 W

PTO	19 W	19 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3573 kWh	4211 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	218 %	174 %
Prated	14.46 kW	13.77 kW
SCOP	5.66	4.56
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.73 kW	8.32 kW
COP Tj = -7°C	5.32	4.24

Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.30 kW	5.05 kW
COP Tj = +2°C	6.15	4.94
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.40 kW	3.24 kW
COP Tj = +7°C	6.27	5.24
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.29 kW	2.23 kW
COP Tj = 12°C	6.12	5.44
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.46 kW	13.77 kW
COP Tj = Tbiv	4.30	3.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.46 kW	13.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.30	3.26
WTOL	75 °C	75 °C
Poff	19 W	19 W
PTO	19 W	19 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	6298 kWh	7451 kWh

Model: WPE-I 12 H(W) 230 GB Premium

Configure model	
Model name	WPE-I 12 H(W) 230 GB Premium
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	n/a

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.19 kW	4.20 kW
El input	0.84 kW	1.34 kW
COP	5.01	3.13

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	216 %	169 %
Prated	12.03 kW	11.99 kW
SCOP	5.59	4.42
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.61 kW	10.59 kW
COP Tj = -7°C	4.81	3.55
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.45 kW	6.44 kW
COP Tj = +2°C	5.72	4.49
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.14 kW	4.13 kW
COP Tj = +7°C	6.12	4.99
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.30 kW	2.21 kW

COP Tj = 12°C	6.29	5.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.03 kW	11.99 kW
COP Tj = Tbiv	4.53	3.29
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.03 kW	11.99 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.53	3.29
WTOL	75 °C	75 °C
Poff	19 W	19 W
PTO	19 W	19 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4445 kWh	5607 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

η_s	214 %	168 %
Prated	12.03 kW	11.99 kW
SCOP	5.55	4.39
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	12.03 kW	11.99 kW
COP Tj = +2°C	4.53	3.29
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	7.71 kW	7.69 kW
COP Tj = +7°C	5.51	4.12
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.41 kW	3.41 kW
COP Tj = 12°C	6.14	5.10
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.03 kW	11.99 kW
COP Tj = Tbiv	4.53	3.29
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.03 kW	11.99 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.53	3.29
WTOL	75 °C	75 °C
Poff	19 W	19 W

PTO	19 W	19 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2896 kWh	3650 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	224 %	174 %
Prated	12.03 kW	11.99 kW
SCOP	5.80	4.56
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.26 kW	7.24 kW
COP Tj = -7°C	5.69	4.31

Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.41 kW	4.40 kW
COP Tj = +2°C	6.16	4.91
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.82 kW	2.82 kW
COP Tj = +7°C	6.19	5.16
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.29 kW	2.23 kW
COP Tj = 12°C	6.12	5.40
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.03 kW	11.99 kW
COP Tj = Tbiv	4.53	3.29
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.03 kW	11.99 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.53	3.29
WTOL	75 °C	75 °C
Poff	19 W	19 W
PTO	19 W	19 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	5108 kWh	6485 kWh

Model: WPE-I 15 H(W) 230 GB Premium

Configure model	
Model name	WPE-I 15 H(W) 230 GB Premium
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	n/a

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	5.18 kW	4.72 kW
El input	1.07 kW	1.48 kW
COP	4.86	3.18

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	210 %	168 %
Prated	14.46 kW	13.77 kW
SCOP	5.44	4.39
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.77 kW	12.16 kW
COP Tj = -7°C	4.46	3.40
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	7.76 kW	7.40 kW
COP Tj = +2°C	5.51	4.44
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.98 kW	4.75 kW
COP Tj = +7°C	6.13	5.03
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.29 kW	2.22 kW

COP Tj = 12°C	6.18	5.31
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.46 kW	13.77 kW
COP Tj = Tbiv	4.30	3.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.46 kW	13.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.30	3.26
WTOL	75 °C	75 °C
Poff	19 W	19 W
PTO	19 W	19 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5489 kWh	6476 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

η_s	208 %	167 %
Prated	14.46 kW	13.77 kW
SCOP	5.41	4.37
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	14.46 kW	13.77 kW
COP Tj = +2°C	4.30	3.26
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	9.27 kW	8.83 kW
COP Tj = +7°C	5.13	3.99
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.11 kW	3.92 kW
COP Tj = 12°C	6.17	5.16
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.46 kW	13.77 kW
COP Tj = Tbiv	4.30	3.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.46 kW	13.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.30	3.26
WTOL	75 °C	75 °C
Poff	19 W	19 W

PTO	19 W	19 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3573 kWh	4211 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	218 %	174 %
Prated	14.46 kW	13.77 kW
SCOP	5.66	4.56
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.73 kW	8.32 kW
COP Tj = -7°C	5.32	4.24

Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.30 kW	5.05 kW
COP Tj = +2°C	6.15	4.94
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.40 kW	3.24 kW
COP Tj = +7°C	6.27	5.24
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.29 kW	2.23 kW
COP Tj = 12°C	6.12	5.44
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.46 kW	13.77 kW
COP Tj = Tbiv	4.30	3.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.46 kW	13.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.30	3.26
WTOL	75 °C	75 °C
Poff	19 W	19 W
PTO	19 W	19 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	6298 kWh	7451 kWh