

Page 1 of 11

This information was generated by the HP KEYMARK database on 18 Mar 2022

LOGIII	I			
Summary of	VITOCAL 100 A- (AF) 16/18	Reg. No.	ICIM-PDC-000088-00	
Certificate Holder				
Name	Viessmann Werke Allendorf Gmb	Viessmann Werke Allendorf GmbH		
Address	Viessmannstraße 1	Zip	35107	
City	Allendorf/Eder	Country	Germany	
Certification Body	ICIM S.p.A.	·		
Subtype title	VITOCAL 100 A- (AF) 16/18			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R32			
Mass of Refrigerant	4 kg	4 kg		
Certification Date	25.06.2020			
Testing basis	HP KEYMARK certification scheme rules rev. no. 7			



Model: AWO-M-AC (AF) 101.A16

Configure model		
Model name	AWO-M-AC (AF) 101.A16	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	+7°C/12°C	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.30 kW	14.89 kW
El input	3.49 kW	5.07 kW
СОР	4.67	2.94

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	177 %	126 %
Prated	14.00 kW	13.00 kW
SCOP	4.49	3.22
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	12.00 kW	11.50 kW
COP Tj = -7°C	2.88	2.09
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.30 kW	6.90 kW
COP Tj = +2°C	4.33	3.06
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.70 kW	5.50 kW
COP Tj = +7°C	5.83	4.11
Cdh Tj = +7 °C	0.98	0.97

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



This information was gener	ated by the HP KEYMA	RK database on 18 Mar 202
Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.12	6.30
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.00 kW	11.50 kW
COP Tj = Tbiv	2.88	2.09
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	11.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.94
WTOL	60 °C	60 °C
Poff	19 W	19 W
РТО	19 W	19 W
PSB	19 W	19 W
РСК	30 W	30 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	6210 kWh	8359 kWh

Cooling


CEN heat pump KEYMARK





EN 14511-2		
+7°C/+12°C		
El input	4.38 kW	
Cooling capacity	13.80	
EER	3.15	

EN 14825





This information was generated by the HP KETMARK database on 16 Mai 202				
+7°C/+12°C				
13.80 kW				
4.80				
13.80 kW				
3.15				
10.17 kW				
4.36				
1.0				
6.47 kW				
5.30				
1.0				
5.53 kW				
6.53				
1.0				
19 W				
0 W				
19 W				
30 W				
1726 kWh				



Model: AWO-AC (AF) 101.A16

Configure model		
Model name	AWO-AC (AF) 101.A16	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	+7°C/12°C	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.30 kW	14.89 kW
El input	3.49 kW	5.07 kW
СОР	4.67	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	naccod
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	177 %	126 %
Prated	14.00 kW	13.00 kW
SCOP	4.49	3.22
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	12.00 kW	11.50 kW
COP Tj = -7°C	2.88	2.09
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.30 kW	6.90 kW
COP Tj = +2°C	4.33	3.06
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.70 kW	5.50 kW
COP Tj = +7°C	5.83	4.11
Cdh Tj = +7 °C	0.98	0.97


EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.12	6.30
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.00 kW	11.50 kW
COP Tj = Tbiv	2.88	2.09
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	11.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.94
WTOL	60 °C	60 °C
Poff	19 W	19 W
РТО	19 W	19 W
PSB	19 W	19 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	6210 kWh	8359 kWh

Cooling





EN 14511-2	
	+7°C/+12°C
El input	4.38 kW
Cooling capacity	13.80
EER	3.15

EN 14825



$$\operatorname{Page}\ 11$$ of 11 This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
Pdesignc	13.80 kW
SEER	4.80
Pdc Tj = 35°C	13.80 kW
EER Tj = 35°C	3.15
Pdc Tj = 30°C	10.17 kW
EER Tj = 30°C	4.36
Cdc	1.0
Pdc Tj = 25°C	6.47 kW
EER Tj = 25°C	5.30
Cdc	1.0
Pdc Tj = 20°C	5.53 kW
EER Tj = 20°C	6.53
Cdc	1.0
Poff	19 W
PTO	o w
PSB	19 W
PCK	30 W
Annual energy consumption Qce	1726 kWh