

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	DAIKIN ALTHERMA LT MONOBLOC / ROTEX HPSU MONOBLOC 5 KW		Reg. No.	011-1W0079
Certificate Holder				
Name	DAIKIN Europe N.V.			
Address	Zandvoordestraat 300		Zip	B-8400
City	Oostende		Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Name of testing laboratory	CEIS			
Subtype title	DAIKIN ALTHERMA LT MONOBLOC / ROTEX HPSU MONOBLOC 5 KW			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R410a			
Mass Of Refrigerant	1.3 kg			

Model: RBLQ05C*V3

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70
Indoor water flow rate	0.76 m ³ /h	0.52 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.10 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	4.36 kW	4.20 kW
COP Tj = TOL	2.52	1.65
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.04 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh

Model: RDLQ05C*V3

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70
Indoor water flow rate	0.76 m ³ /h	0.52 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.34 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	4.36 kW	4.20 kW
COP Tj = TOL	2.52	1.65
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.04 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh

Model: EDLQ05C*V3

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70
Indoor water flow rate	0.76 m ³ /h	0.52 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.34 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	4.36 kW	4.20 kW
COP Tj = TOL	2.52	1.65
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.04 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh

Model: EBLQ05C*V3

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70
Indoor water flow rate	0.76 m ³ /h	0.52 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.10 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	4.36 kW	4.20 kW
COP Tj = TOL	2.52	1.65
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.04 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh