

This information was generated by the HP KEYMARK database on 8 Mar 2021

Summary of	DAITSU MONOBLOC 3D SMART 14	Reg. No.	041-K010-01
Certificate Holder			
Name	Eurofred S.A.		
Address	Marqués de Sentmenat, 97	Zip	08029
City	Barcelona	Country	Spain
Certification Body	BRE Global Limited		
Subtype title	DAITSU MONOBLOC 3D SMART 14		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	1 kg		
Certification Date	08.03.2021		
Testing basis	Heat Pump Keymark Scheme Rules Rev 08		

Model: AOWD-MB SMART-14K + WITD-AQUATANK MB-300

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Medium temperature
Heat output	2.78 kW
El input	1.32 kW
COP	2.11

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Medium temperature
Sound power level outdoor	64 dB(A)

EN 14825

	Medium temperature
η_s	127 %
Prated	6.00 kW
SCOP	3.26
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	5.22 kW
COP Tj = -7°C	2.22
Cdh	0.970
Pdh Tj = +2°C	3.31 kW
COP Tj = +2°C	3.13
Cdh	0.970
Pdh Tj = +7°C	2.46 kW
COP Tj = +7°C	4.19
Cdh	0.970
Pdh Tj = 12°C	2.98 kW
COP Tj = 12°C	5.52
Cdh	0.970
Pdh Tj = Tbiv	5.22 kW
COP Tj = Tbiv	2.22

This information was generated by the HP KEYMARK database on 8 Mar 2021

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.34 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.78
WTOL	55 °C
Poff	18 W
PTO	18 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	1.66 kW
Annual energy consumption Qhe	3808 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.53
Heating up time	2.59 h:min
Standby power input	62.2 W
Reference hot water temperature	51.7 °C
Mixed water at 40°C	379 l