

Summary of	WPF 10 basic	Reg. No.	011-1W0018
Certificate Holder		·	
Name	STIEBEL ELTRON GmbH & Co	KG	
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH	
Subtype title	WPF 10 basic		
Heat Pump Type	Brine/Water		
Refrigerant	R410a		
Mass Of Refrigerant	2.6 kg		
Certification Date	25.08.2016	25.08.2016	



## Model: WPF 10 basic, all climates

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-2	
	Low temperature
Heat output	9.70 kW
El input	2.22 kW
СОР	4.37
Indoor water flow rate	1.71 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	failed
Starting and operating test	passed

## Average Climate



EN 12102-1	
	Low temperature
Sound power level indoor	58 dB(A)

EN 14825	
	Low temperature
$\eta_s$	190 %
Prated	10.00 kW
SCOP	4.94
Tbiv	-10 °C
TOL	-20 °C
Pdh Tj = -7°C	9.70 kW
$COP Tj = -7^{\circ}C$	4.44
Cdh	0.90
Pdh Tj = +2°C	9.80 kW
COP Tj = +2°C	4.85
Cdh	0.90
Pdh Tj = +7°C	10.00 kW
COP Tj = +7°C	5.28
Cdh	0.90
Pdh Tj = 12°C	10.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C	5.78
Cdh	0.90
Pdh Tj = Tbiv	9.70 kW
COP Tj = Tbiv	4.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.37
WTOL	60 °C
Poff	o w
РТО	78 W
PSB	3 W
PCK	o w
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	4053 kWh

## Warmer Climate

EN 14825	
	Low temperature
$\eta_{s}$	190 %
Prated	10.00 kW
SCOP	4.95





Tbiv	2 °C
TOL	0 °C
Pdh Tj = +2°C	9.70 kW
$COP Tj = +2^{\circ}C$	4.37
Cdh	0.90
Pdh Tj = +7°C	9.80 kW
$COPTj = +7^{\circ}C$	4.76
Cdh	0.90
Pdh Tj = 12°C	10.00 kW
COP Tj = 12°C	5.44
Cdh	0.90
Pdh Tj = Tbiv	9.70 kW
COP Tj = Tbiv	4.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.37
WTOL	60 °C
Poff	o w
PTO	78 W
PSB	3 W
PCK	o w
Supplementary Heater: Type of energy input	electricity





Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2617 kWh

EN 12102-1	
	Low temperature
Sound power level indoor	58 dB(A)

## Colder Climate

EN 14825	
	Low temperature
$\eta_{s}$	199 %
Prated	12.00 kW
SCOP	5.17
Tbiv	-15 °C
TOL	-22 °C
Pdh Tj = -7°C	9.90 kW
COP Tj = -7°C	5.07
Cdh	0.90
Pdh Tj = +2°C	10.00 kW
COP Tj = +2°C	5.41
Cdh	0.90

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP REYMARK database on 18 Dec 2020			
Pdh Tj = +7°C	10.10 kW		
$COP Tj = +7^{\circ}C$	5.70		
Cdh	0.90		
Pdh Tj = 12°C	10.10 kW		
COP Tj = 12°C	5.75		
Cdh	0.90		
Pdh Tj = Tbiv	9.90 kW		
COP Tj = Tbiv	4.93		
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.90 kW		
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.93		
WTOL	60 °C		
Poff	0 W		
PTO	78 W		
PSB	3 W		
PCK	0 W		
Supplementary Heater: Type of energy input	electricity		
Supplementary Heater: PSUP	2.40 kW		
Annual energy consumption Qhe	5768 kWh		
Pdh Tj = -15°C (if TOL<-20°C)	9.90		
COP Tj = $-15$ °C (if TOL< $-20$ °C)	4.93		
Cdh	0.90		





EN 12102-1	
	Low temperature
Sound power level indoor	58 dB(A)



## Model: WPF 10 basic, average climates

General Data		
Power supply 3x400V 50Hz		

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	9.70 kW	8.57 kW
El input	2.22 kW	3.67 kW
СОР	4.37	2.34
Indoor water flow rate	1.71 m³/h	1.22 m³/h

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	failed	
Starting and operating test	passed	

## **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	190 %	114 %
Prated	10.00 kW	9.00 kW
SCOP	4.94	3.06
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	8.70 kW
COP Tj = -7°C	4.44	2.46
Cdh	0.90	0.90
Pdh Tj = +2°C	9.80 kW	9.10 kW
COP Tj = +2°C	4.85	2.99
Cdh	0.90	0.90
Pdh Tj = +7°C	10.00 kW	9.30 kW
COP Tj = +7°C	5.28	3.42
Cdh	0.90	0.90
Pdh Tj = 12°C	10.10 kW	9.50 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



# $$\operatorname{Page}\ 11$$ of 11 This information was generated by the HP KEYMARK database on 18 Dec 2020

COP Tj = 12°C	5.78	3.95
Cdh	0.90	0.90
Pdh Tj = Tbiv	9.70 kW	8.60 kW
COP Tj = Tbiv	4.37	2.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.70 kW	8.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.37	2.34
WTOL	60 °C	60 °C
Poff	o w	0 W
РТО	78 W	78 W
PSB	3 W	3 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4053 kWh	5788 kWh