

Summary of	WPF 13 basic	Reg. No.	011-1W0012
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	VDE Prüf- und Zertifizierungsinstitut		
Subtype title	WPF 13 basic		
Heat Pump Type	Brine/Water		
Refrigerant	R410a		
Mass Of Refrigerant	2.5 kg		
Certification Date	25.08.2016		



Model: WPF 13 basic, all climates

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	
Heat output	12.59 kW	
El input	2.85 kW	
СОР	4.42	
Indoor water flow rate	2.21 m³/h	

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	failed
Starting and operating test	passed

Average Climate



EN 12102-1	
	Low temperature
Sound power level indoor	60 dB(A)

EN 14825	
	Low temperature
η_{s}	189 %
Prated	13.00 kW
SCOP	4.92
Tbiv	-10 °C
TOL	-20 °C
Pdh Tj = -7° C	12.60 kW
COP Tj = -7°C	4.48
Cdh	0.90
Pdh Tj = +2°C	12.70 kW
COP Tj = +2°C	4.84
Cdh	0.90
Pdh Tj = $+7^{\circ}$ C	12.80 kW
$COPTj = +7^{\circ}C$	5.21
Cdh	0.90
Pdh Tj = 12°C	12.90 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C	5.63
Cdh	0.90
Pdh Tj = Tbiv	12.60 kW
COP Tj = Tbiv	4.42
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.42
WTOL	60 °C
Poff	0 W
PTO	78 W
PSB	3 W
PCK	o w
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	5285 kWh

Warmer Climate

EN 14825	
	Low temperature
η_{s}	189 %
Prated	13.00 kW
SCOP	4.94





This information was generated by the Fill Remi	
Tbiv	2 °C
TOL	0 °C
Pdh Tj = +2°C	12.60 kW
COP Tj = +2°C	4.42
Cdh	0.90
Pdh Tj = +7°C	12.70 kW
$COP Tj = +7^{\circ}C$	4.76
Cdh	0.90
Pdh Tj = 12°C	12.90 kW
COP Tj = 12°C	5.34
Cdh	0.90
Pdh Tj = Tbiv	12.60 kW
COP Tj = Tbiv	4.42
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.42
WTOL	60 °C
Poff	0 W
РТО	78 W
PSB	3 W
PCK	o w
Supplementary Heater: Type of energy input	electricity





Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	3407 kWh

EN 12102-1	
	Low temperature
Sound power level indoor	60 dB(A)

Colder Climate

EN 14825	
	Low temperature
η_{S}	196 %
Prated	16.00 kW
SCOP	5.10
Tbiv	-15 °C
TOL	-22 °C
Pdh Tj = -7°C	12.80 kW
$COP Tj = -7^{\circ}C$	5.02
Cdh	0.90
Pdh Tj = $+2$ °C	12.80 kW
$COP Tj = +2^{\circ}C$	5.31
Cdh	0.90

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





Pdh Tj = $+7^{\circ}$ C	12.90 kW
$COP Tj = +7^{\circ}C$	5.56
Cdh	0.90
Pdh Tj = 12°C	12.90 kW
COP Tj = 12°C	5.60
Cdh	0.90
Pdh Tj = Tbiv	12.70 kW
COP Tj = Tbiv	4.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.90
WTOL	60 °C
Poff	o w
РТО	78 W
PSB	3 W
PCK	o w
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	3.02 kW
Annual energy consumption Qhe	7542 kWh
Pdh Tj = -15°C (if TOL<-20°C)	12.70
COP Tj = -15 °C (if TOL< -20 °C)	4.90
Cdh	0.90





EN 12102-1		
	Low temperature	
Sound power level indoor	60 dB(A)	



Model: WPF 13 basic, average climates

General Data		
Power supply 3x400V 50Hz		

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.59 kW	11.60 kW
El input	2.85 kW	4.52 kW
СОР	4.42	2.57
Indoor water flow rate	2.21 m³/h	1.58 m³/h

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	failed	
Starting and operating test	passed	

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	189 %	122 %
Prated	13.00 kW	12.00 kW
SCOP	4.92	3.26
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-10 °C
Pdh Tj = -7°C	12.60 kW	11.70 kW
COP Tj = -7°C	4.48	2.69
Cdh	0.90	0.90
Pdh Tj = +2°C	12.70 kW	12.00 kW
COP Tj = +2°C	4.84	3.20
Cdh	0.90	0.90
Pdh Tj = +7°C	12.80 kW	12.30 kW
$COP Tj = +7^{\circ}C$	5.21	3.60
Cdh	0.90	0.90
Pdh Tj = 12°C	12.90 kW	12.50 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



$$\operatorname{\textit{Page}}\ 11$$ of 11 This information was generated by the HP KEYMARK database on 18 Dec 2020

COP Tj = 12°C	5.63	4.09
Cdh	0.90	0.90
Pdh Tj = Tbiv	12.60 kW	11.60 kW
COP Tj = Tbiv	4.42	2.57
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.60 kW	11.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.42	2.57
WTOL	60 °C	60 °C
Poff	o w	0 W
РТО	78 W	78 W
PSB	3 W	3 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5285 kWh	7350 kWh