

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	NIBE AMS 20-6	Reg. No.	012-C700084
Certificate Holder			
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Subtype title	NIBE AMS 20-6		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.3 kg		
Certification Date	08.12.2020		
Testing basis	HP Keymark Scheme Rules rev 8		

Model: NIBE AMS 20-6 + HBS 20-6

Configure model	
Model name	NIBE AMS 20-6 + HBS 20-6
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.08 kW	4.16 kW
El input	0.98 kW	1.36 kW
COP	5.17	3.06

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	200 %	139 %
Prated	5.20 kW	5.60 kW
SCOP	5.08	3.56
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.54 kW	5.04 kW
COP Tj = -7°C	3.04	1.95
Cdh Tj = -7 °C	0.99	1.00
Pdh Tj = +2°C	2.70 kW	2.89 kW
COP Tj = +2°C	5.00	3.51
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	1.78 kW	1.89 kW
COP Tj = +7°C	6.67	4.99
Cdh Tj = +7 °C	0.96	0.97

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	1.83 kW	1.74 kW
COP Tj = 12°C	8.54	6.33
Cdh Tj = +12 °C	0.95	0.96
Pdh Tj = Tbiv	5.23 kW	5.04 kW
COP Tj = Tbiv	2.61	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.23 kW	4.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.61	1.74
WTOL	58 °C	58 °C
Poff	7 W	7 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	1.00 kW
Annual energy consumption Qhe	2116 kWh	3250 kWh