

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	NEVIS PLUS R32 25 MUD0	Reg. No.	ICIM-PDC-000100
Certificate Holder			
Name	Ariston Thermo Group		
Address	Viale Aristide Merloni 45	Zip	I-60044
City	Fabriano (AN)	Country	Italy
Certification Body	ICIM S.p.A.		
Subtype title	NEVIS PLUS R32 25 MUD0		
Heat Pump Type	Air/Air Single Split		
Refrigerant	R32		
Mass of Refrigerant	0.62 kg		
Certification Date	07.06.2021		
Testing basis	V9		

Model: NEVIS PLUS R32 25 MUD0

Configure model	
Model name	NEVIS PLUS R32 25 MUD0
Application	Heating + Cooling
Climate zone (for heating)	n/a
EN14511-2 certification (heating mode)	Yes

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2	
	A35/A27
Heating capacity	2.93
El input	0.67 kW
COP	4.40

Cooling

EN 14511-2	
El input	0.63 kW
Cooling capacity	2.60
EER	4.14

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 12102-1

Sound power level indoor	53 dB(A)
Sound power level outdoor	59 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 22 Jun 2022

	Indoor dry(wet) bulb temperature 27(19)°C
P _{designc}	2.60 kW
SEER	8.80
P _{dc Tj = 35°C}	2.60 kW
EER T _j = 35°C	4.20
P _{dc Tj = 30°C}	1.75 kW
EER T _j = 30°C	6.66
C _{dc}	0.3
P _{dc Tj = 25°C}	1.11 kW
EER T _j = 25°C	10.90
C _{dc}	0.3
P _{dc Tj = 20°C}	0.90 kW
EER T _j = 20°C	15.00
C _{dc}	0.3
P _{off}	1 W
PTO	12 W
PSB	1 W
PCK	0 W
Annual energy consumption Q _{ce}	103 kWh

Average Climate

EN 14825

This information was generated by the HP KEYMARK database on 22 Jun 2022

	Indoor dry bulb temperature: 20°C
P _{designh}	2.40 kW
SCOP	4.60
T _{biv}	-7 °C
TOL	-15 °C
P _{dh} T _j = -7°C	2.12 kW
COP T _j = -7°C	3.20
C _{dh} T _j = -7 °C	0.250
P _{dh} T _j = +2°C	1.30 kW
COP T _j = +2°C	4.60
C _{dh} T _j = +2 °C	0.250
P _{dh} T _j = +7°C	0.84 kW
COP T _j = +7°C	5.60
C _{dh} T _j = +7 °C	0.250
P _{dh} T _j = 12°C	0.60 kW
COP T _j = 12°C	6.50
C _{dh} T _j = +12 °C	0.250
P _{dh} T _j = T _{biv}	2.12 kW
COP T _j = T _{biv}	3.20
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	2.39 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.50
P _{off}	1 W

This information was generated by the HP KEYMARK database on 22 Jun 2022

PTO	12 W
PSB	1 W
PCK	0 W
Backup Heater	0.00 kW
Annual energy consumption Q _{he}	730 kWh