

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	04. Yutaki S 2.5HP R32	Reg. No.	041-K002-32
Certificate Holder			
Name	Johnson Controls-Hitachi AirConditioning Spain		
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella	Zip	08233
City	Vacarisses, Barcelona	Country	Spain
Certification Body	BRE Global Limited		
Subtype title	04. Yutaki S 2.5HP R32		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.3 kg		
Certification Date	02.08.2019		

Model: 01. RAS-2.5WHVRP RWM-2.5NRE - Heating Only

Configure model	
Model name	01. RAS-2.5WHVRP RWM-2.5NRE - Heating Only
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	6.00 kW
El input	1.25 kW	2.11 kW
COP	4.80	2.85

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	177 %	127 %
Prated	6.00 kW	5.00 kW
SCOP	4.50	3.25
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.10 kW	4.42 kW
COP Tj = -7°C	2.70	1.85
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.10 kW	2.69 kW
COP Tj = +2°C	4.60	3.30
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	4.60
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.35	6.35
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.10 kW	4.42 kW
COP Tj = Tbiv	2.70	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.30 kW	3.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.70
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.25 kW	1.10 kW
Annual energy consumption Qhe	2652 kWh	3186 kWh

Model: 02. RAS-2.5WHVRP RWM-2.5NRE - with cooling kit

Configure model	
Model name	02. RAS-2.5WHVRP RWM-2.5NRE - with cooling kit
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.00 kW	6.00 kW
El input	1.25 kW	2.11 kW
COP	4.80	2.85

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	180 %	128 %
Prated	6.00 kW	5.00 kW
SCOP	4.58	3.28
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.10 kW	4.42 kW
COP Tj = -7°C	2.70	1.85
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.10 kW	2.69 kW
COP Tj = +2°C	4.60	3.30
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	4.60
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.35	6.35
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.10 kW	4.42 kW
COP Tj = Tbiv	2.70	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.30 kW	3.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.50	1.70
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.25 kW	1.10 kW
Annual energy consumption Qhe	2608 kWh	3143 kWh

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.47 kW	1.19 kW
Cooling capacity	5.3	6.3
EER	3.6	5.3

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C	+18°C/+23°C
P _{designc}	5.3 kW	6.3 kW
SEER	5.53	8.5
P _{dc} T _j = 35°C	5.3 kW	6.3 kW
EER T _j = 35°C	3.6	5.3
P _{dc} T _j = 30°C	3.91 kW	4.64 kW
EER T _j = 30°C	4.5	7
C _{dc}	1	1
P _{dc} T _j = 25°C	2.51 kW	2.98 kW
EER T _j = 25°C	6.3	9.9
C _{dc}	1	1
P _{dc} T _j = 20°C	2.88 kW	2.65 kW
EER T _j = 20°C	8.56	12.6
C _{dc}	0.9	0.9
P _{off}	12 W	12 W
P _{TO}	0 W	0 W
P _{SB}	12 W	12 W
P _{CK}	0 W	0 W
Annual energy consumption Q _{ce}	575 kWh	337 kWh