

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Ecodan Zubadan 14-200D Packaged	Reg. No.	037-0035-20
Certificate Holder			
Name	Mitsubishi Electric Air Conditioning Systems Europe LTD		
Address	Nettlehill Road, Houston Industrial Estate	Zip	EH54 5EQ
City	Livingston	Country	United Kingdom
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	Ecodan Zubadan 14-200D Packaged		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	3.3 kg		
Certification Date	27.07.2020		
Testing basis	HP Keymark scheme rules rev. no. 6		

Model: PUZ-HWM140VHA(-BS) + EHPT20X-M*D

Configure model	
Model name	PUZ-HWM140VHA(-BS) + EHPT20X-M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	132 %
Prated	14 kW	14 kW
SCOP	4.47	3.37
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.4	3.25
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.28	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6470 kWh	8589 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	227 %	160 %
Prated	14 kW	14 kW
SCOP	5.75	4.07
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.1	3.25
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Q _{he}	3252 kWh	4593 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.07
Heating up time	01:46 h:min
Standby power input	38 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	152 %
COP	3.58
Heating up time	01:34 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUZ-HWM140VHA(-BS) + EHPT20X-*M*D

Configure model	
Model name	PUZ-HWM140VHA(-BS) + EHPT20X-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	132 %
Prated	14 kW	14 kW
SCOP	4.47	3.37
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.4	3.25
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.28	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6470 kWh	8589 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	227 %	160 %
Prated	14 kW	14 kW
SCOP	5.75	4.07
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.1	3.25
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Q _{he}	3252 kWh	4593 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.07
Heating up time	01:46 h:min
Standby power input	38 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	152 %
COP	3.58
Heating up time	01:34 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUZ-HWM140VHA(-BS) + EHPX-M*D

Configure model	
Model name	PUZ-HWM140VHA(-BS) + EHPX-M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	132 %
Prated	14 kW	14 kW
SCOP	4.47	3.37
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.4	3.25
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.28	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6470 kWh	8589 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	227 %	160 %
Prated	14 kW	14 kW
SCOP	5.75	4.07
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.1	3.25
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	3252 kWh	4593 kWh

Model: PUZ-HWM140VHA(-BS) + EHPX-*M*D

Configure model	
Model name	PUZ-HWM140VHA(-BS) + EHPX-*M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	132 %
Prated	14 kW	14 kW
SCOP	4.47	3.37
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.4	3.25
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.28	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6470 kWh	8589 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	227 %	160 %
Prated	14 kW	14 kW
SCOP	5.75	4.07
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.1	3.25
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	3252 kWh	4593 kWh

Model: PUZ-HWM140VHA(-BS) + ERPT20X-M*D

Configure model	
Model name	PUZ-HWM140VHA(-BS) + ERPT20X-M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	133 %
Prated	14 kW	14 kW
SCOP	4.51	3.39
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.4	3.25
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.28	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6407 kWh	8534 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	232 %	162 %
Prated	14 kW	14 kW
SCOP	5.87	4.13
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.1	3.25
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Q _{he}	3186 kWh	4527 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.07
Heating up time	01:46 h:min
Standby power input	38 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	152 %
COP	3.58
Heating up time	01:34 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUZ-HWM140VHA(-BS) + ERPT20X-*M*D

Configure model	
Model name	PUZ-HWM140VHA(-BS) + ERPT20X-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	133 %
Prated	14 kW	14 kW
SCOP	4.51	3.39
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.4	3.25
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.28	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6407 kWh	8534 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	232 %	162 %
Prated	14 kW	14 kW
SCOP	5.87	4.13
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.1	3.25
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Q _{he}	3186 kWh	4527 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.07
Heating up time	01:46 h:min
Standby power input	38 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Warmer Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	152 %
COP	3.58
Heating up time	01:34 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUZ-HWM140VHA(-BS)

Configure model	
Model name	PUZ-HWM140VHA(-BS)
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	178 %	133 %
Prated	14 kW	14 kW
SCOP	4.51	3.39
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.4	3.25
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.28	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6407 kWh	8534 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	232 %	162 %
Prated	14 kW	14 kW
SCOP	5.87	4.13
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.1	3.25
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	3186 kWh	4527 kWh

Model: PUZ-HWM140YHA(-BS) + EHPT20X-M*D

Configure model	
Model name	PUZ-HWM140YHA(-BS) + EHPT20X-M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	131 %
Prated	14 kW	14 kW
SCOP	4.46	3.36
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.42	3.26
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.26	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6492 kWh	8608 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	225 %	159 %
Prated	14 kW	14 kW
SCOP	5.69	4.04
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.12	3.26
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Q _{he}	3288 kWh	4628 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.07
Heating up time	01:46 h:min
Standby power input	38 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Warmer Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	152 %
COP	3.58
Heating up time	01:34 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUZ-HWM140YHA(-BS) + EHPT20X-*M*D

Configure model	
Model name	PUZ-HWM140YHA(-BS) + EHPT20X-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	131 %
Prated	14 kW	14 kW
SCOP	4.46	3.36
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.42	3.26
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.26	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6492 kWh	8608 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	225 %	159 %
Prated	14 kW	14 kW
SCOP	5.69	4.04
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.12	3.26
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Q _{he}	3288 kWh	4628 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.07
Heating up time	01:46 h:min
Standby power input	38 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Warmer Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	152 %
COP	3.58
Heating up time	01:34 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUZ-HWM140YHA(-BS) + EHPX-M*D

Configure model	
Model name	PUZ-HWM140YHA(-BS) + EHPX-M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	131 %
Prated	14 kW	14 kW
SCOP	4.46	3.36
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.42	3.26
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.26	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6492 kWh	8608 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	225 %	159 %
Prated	14 kW	14 kW
SCOP	5.69	4.04
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.12	3.26
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	3288 kWh	4628 kWh

Model: PUZ-HWM140YHA(-BS) + EHPX-*M*D

Configure model	
Model name	PUZ-HWM140YHA(-BS) + EHPX-*M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	131 %
Prated	14 kW	14 kW
SCOP	4.46	3.36
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.42	3.26
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.26	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6492 kWh	8608 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	225 %	159 %
Prated	14 kW	14 kW
SCOP	5.69	4.04
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.12	3.26
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Q _{he}	3288 kWh	4628 kWh

Model: PUZ-HWM140YHA(-BS) + ERPT20X-M*D

Configure model	
Model name	PUZ-HWM140YHA(-BS) + ERPT20X-M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	177 %	133 %
Prated	14 kW	14 kW
SCOP	4.51	3.39
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.42	3.26
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.26	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6412 kWh	8528 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	231 %	162 %
Prated	14 kW	14 kW
SCOP	5.86	4.13
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.12	3.26
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Q _{he}	3191 kWh	4531 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.07
Heating up time	01:46 h:min
Standby power input	38 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Warmer Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	152 %
COP	3.58
Heating up time	01:34 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUZ-HWM140YHA(-BS) + ERPT20X-*M*D

Configure model	
Model name	PUZ-HWM140YHA(-BS) + ERPT20X-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	177 %	133 %
Prated	14 kW	14 kW
SCOP	4.51	3.39
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.42	3.26
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.26	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6412 kWh	8528 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	231 %	162 %
Prated	14 kW	14 kW
SCOP	5.86	4.13
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.12	3.26
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Q _{he}	3191 kWh	4531 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.07
Heating up time	01:46 h:min
Standby power input	38 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	152 %
COP	3.58
Heating up time	01:34 h:min
Standby power input	35 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	278 l

Model: PUZ-HWM140YHA(-BS)

Configure model	
Model name	PUZ-HWM140YHA(-BS)
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14 kW	14 kW
El input	3.14 kW	5.24 kW
COP	4.46	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	177 %	133 %
Prated	14 kW	14 kW
SCOP	4.51	3.39
Tbiv	-7 °C	-7 °C
TOL	-28 °C	-28 °C
Pdh Tj = -7°C	12.4 kW	12.4 kW
COP Tj = -7°C	2.55	1.98
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	7.5 kW	7.5 kW
COP Tj = +2°C	4.42	3.26
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.1 kW
COP Tj = +7°C	6.26	4.64
Cdh Tj = +7 °C	0.98	0.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.7 kW	5.2 kW
COP Tj = 12°C	7.43	6.24
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.4 kW	12.4 kW
COP Tj = Tbiv	2.55	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.9 kW	13.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.75
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.1 kW	0.1 kW
Annual energy consumption Qhe	6412 kWh	8528 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	231 %	162 %
Prated	14 kW	14 kW
SCOP	5.86	4.13
Tbiv	2 °C	2 °C
TOL	-28 °C	-28 °C
Pdh Tj = +2°C	14 kW	14 kW
COP Tj = +2°C	3.15	1.94
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	9 kW	9 kW
COP Tj = +7°C	5.12	3.26
Cdh Tj = +7 °C	0.99	1
Pdh Tj = 12°C	5.5 kW	5.2 kW
COP Tj = 12°C	7.43	5.91
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	14 kW	14 kW
COP Tj = Tbiv	3.15	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14 kW	14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.94
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	3191 kWh	4531 kWh