

Page 1 of 8

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	VWF 197/4	Reg. No.	40046302	
Certificate H	Certificate Holder			
Name	Vaillant Deutschland GmbH & Co KG			
Address	Berghauser Straße 40	Zip	42859	
City	Remscheid	Country	Germany	
Certification Body	VDE Testing and Certification Institute GmbH			
Subtype title	VWF 197/4			
Heat Pump Type	Brine/Water			
Refrigerant	R410A			
Mass of Refrigerant	3.95 kg			
Certification Date	28.04.2021			
Testing basis	DIN EN 14511-1:2019-07; EN 14511-1:2018 DIN EN 14511-2:2019-07; EN 14511-2:2018 DIN EN 14511-3:2019-07; EN 14511-3:2018 DIN EN 14511-4:2019-07; EN 14511-4:2018 EN 12102-1:2018-02; EN 12102-1:2017			



This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: VWF 197/4

Configure model		
Model name VWF 197/4		
Application	Heating (medium temp)	
Units	Indoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional) n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2			
Low temperature Medium temperature			
Heat output	19.62 kW	19.94 kW	
El input	4.32 kW	6.26 kW	
СОР	4.54	3.18	

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate



This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	- dB(A)	- dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	187 %	142 %
Prated	19.62 kW	19.94 kW
SCOP	4.88	3.75
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	19.61 kW	19.91 kW
COP Tj = -7°C	4.59	3.29
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	19.58 kW	19.79 kW
COP Tj = +2°C	4.83	3.70
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	19.54 kW	19.72 kW
COP Tj = +7°C	5.07	4.01
Cdh Tj = +7 °C	1.00	1.00



	-	
Pdh Tj = 12°C	19.51 kW	19.65 kW
COP Tj = 12°C	5.33	4.39
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	19.62 kW	19.94 kW
COP Tj = Tbiv	4.54	3.18
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	19.62 kW	19.94 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.54	3.18
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	7 W	7 W
РТО	7 W	7 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	8308 kWh	10986 kWh

Warmer Climate



This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	- dB(A)	- dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	189 %	143 %
Prated	19.62 kW	19.94 kW
SCOP	4.93	3.78
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	19.62 kW	19.94 kW
COP Tj = +2°C	4.54	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = $+7^{\circ}$ C	19.58 kW	19.84 kW
$COPTj = +7^{\circ}C$	4.77	3.50
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	19.53 kW	19.69 kW
COP Tj = 12°C	5.16	4.13
Cdh Tj = +12 °C	1.00	1.00





	<u> </u>	
Pdh Tj = Tbiv	19.62 kW	19.94 kW
COP Tj = Tbiv	4.54	3.18
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	19.62 kW	19.94 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.54	3.18
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	7 W	7 W
РТО	7 W	7 W
PSB	7 W	7 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5314 kWh	7057 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	- dB(A)	- dB(A)

EN 14825



Page 7 of 8 This information was generated by the HP KEYMARK database on 18 Mar 2022

_	Low temperature	Medium temperature
η_{s}	191 %	144 %
Prated	19.62 kW	19.94 kW
SCOP	4.98	3.81
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7 °C	19.57 kW	19.81 kW
COP Tj = -7°C	4.86	3.61
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = $+2$ °C	19.54 kW	19.73 kW
$COP Tj = +2^{\circ}C$	5.08	3.95
Cdh Tj = $+2$ °C	1.00	1.00
Pdh Tj = $+7^{\circ}$ C	19.52 kW	19.67 kW
$COP Tj = +7^{\circ}C$	5.25	4.27
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	19.51 kW	19.62 kW
COP Tj = 12°C	5.30	4.54
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	19.62 kW	19.94 kW
COP Tj = Tbiv	4.54	3.18
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL $<$ Tdesignh	19.62 kW	19.94 kW



Page 8 of 8 This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.54	3.18
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	7 W	7 W
РТО	7 W	7 W
PSB	7 W	7 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	9713 kWh	12894 kWh
Cdh Tj = -15 °C	1.00	1.00