This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	CTC GSi 608	Reg. No.	012-C700085
Certificate Holder			
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Name of testing laboratory	DTI, RISE		
Subtype title	CTC GSi 608		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass Of Refrigerant	2.4 kg		
Certification Date	30.11.2020		
Testing basis	HP Keymark Scheme 2019		

Model: CTC GSi 608

General Data	
Power supply	3x400V 50Hz
Off-peak product	No

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.08 kW	5.24 kW
El input	1.27 kW	1.78 kW
COP	4.78	2.95
Indoor water flow rate	1.20 m³/h	0.90 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	34 dB(A)	34 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	208 %	159 %
Prated	7.00 kW	7.00 kW
SCOP	5.39	4.17
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.02 kW	6.58 kW
COP Tj = -7°C	4.75	3.02
Cdh	0.98	0.99
Pdh Tj = +2°C	3.61 kW	4.31 kW
COP Tj = +2°C	5.68	4.71
Cdh	0.96	0.97
Pdh Tj = +7°C	2.47 kW	2.30 kW
COP Tj = +7°C	5.97	4.46
Cdh	0.94	0.94
Pdh Tj = 12°C	2.58 kW	2.28 kW
COP Tj = 12°C	6.05	4.86
Cdh	0.95	0.95
Pdh Tj = Tbiv	7.32 kW	6.91 kW
COP Tj = Tbiv	4.56	2.66

Pdh Tj = TOL	7.32 kW	6.87 kW
COP Tj = TOL	4.56	2.84
Cdh	0.97	0.97
WTOL	65 °C	65 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	0 W	0 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2683 kWh	3467 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	34 dB(A)	34 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	217 %	162 %
Prated	7.00 kW	7.00 kW

SCOP	5.63	4.24
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.18 kW	4.42 kW
COP Tj = -7°C	5.52	4.01
Cdh	0.97	0.98
Pdh Tj = +2°C	2.70 kW	2.33 kW
COP Tj = +2°C	6.11	4.59
Cdh	0.95	0.96
Pdh Tj = +7°C	2.64 kW	2.35 kW
COP Tj = +7°C	6.14	5.15
Cdh	0.95	0.95
Pdh Tj = 12°C	2.64 kW	2.68 kW
COP Tj = 12°C	6.14	5.92
Cdh	0.95	0.95
Pdh Tj = Tbiv	7.32 kW	6.94 kW
COP Tj = Tbiv	4.56	2.88
Pdh Tj = TOL	7.32 kW	6.87 kW
COP Tj = TOL	4.56	2.84
Cdh	0.97	0.97
WTOL	65 °C	65 °C

Poff	23 W	23 W
PTO	23 W	23 W
PSB	0 W	0 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3063 kWh	4065 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	98 %
COP	2.39
Heating up time	01:58 h:min
Standby power input	79.8 W
Reference hot water temperature	49.8 °C
Mixed water at 40°C	239 l

Colder Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	98 %
COP	2.39
Heating up time	01:58 h:min
Standby power input	79.8 W
Reference hot water temperature	49.8 °C
Mixed water at 40°C	239 l