

Page 1 of 6

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

| Summary of | i-HPV5H 0140 | Reg. No. | ICIM-PDC-000133 | |
|---------------------|---------------------------------|----------|-----------------|--|
| Certificate Holder | Certificate Holder | | | |
| Name | Advantix S.p.A. | | | |
| Address | Via San Giuseppe Lavoratore, 24 | Zip | 37040 | |
| City | Arcole Verona | Country | Italy | |
| Certification Body | ICIM S.p.A. | · | | |
| Subtype title | i-HPV5H 0140 | | | |
| Heat Pump Type | Outdoor Air/Water | | | |
| Refrigerant | R32 | | | |
| Mass of Refrigerant | 6.5 kg | | | |
| Certification Date | 25.02.2022 | | | |
| Testing basis | Heat Pump KEYMARK V9 | | | |



Model: i-HPV5H 0140

| Configure model | | |
|-------------------------------------|-----------------------|--|
| Model name | i-HPV5H 0140 | |
| Application | Heating (medium temp) | |
| Units | Outdoor | |
| Climate Zone | n/a | |
| Reversibility | Yes | |
| Cooling mode application (optional) | +7°C/12°C | |

| General Data | | |
|--------------|-------------|--|
| Power supply | 3x400V 50Hz | |

Heating

| EN 14511-2 | | |
|-------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Heat output | 40.00 kW | 38.40 kW |
| El input | 9.84 kW | 14.20 kW |
| СОР | 4.07 | 2.70 |

| EN 14511-4 | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

Average Climate



| EN 12102-1 | | |
|---------------------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Sound power level outdoor | 74 dB(A) | 74 dB(A) |

| EN 14825 | | |
|----------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| η_{s} | 167 % | 126 % |
| Prated | 31.00 kW | 29.00 kW |
| SCOP | 4.25 | 3.23 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -9 °C |
| Pdh Tj = -7°C | 27.10 kW | 25.80 kW |
| COP Tj = -7°C | 2.49 | 1.72 |
| Cdh Tj = -7 °C | 1.000 | 1.000 |
| Pdh Tj = +2°C | 17.60 kW | 17.10 kW |
| COP Tj = +2°C | 4.23 | 3.10 |
| Cdh Tj = +2 °C | 1.000 | 1.000 |
| Pdh Tj = +7°C | 18.00 kW | 20.20 kW |
| COP Tj = +7°C | 5.54 | 4.59 |
| Cdh Tj = +7 °C | 1.000 | 1.000 |
| Pdh Tj = 12°C | 20.20 kW | 22.90 kW |

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



| COP Tj = 12°C | 7.11 | 7.25 |
|---|-----------|-----------|
| Cdh Tj = +12 °C | 1.000 | 1.000 |
| Pdh Tj = Tbiv | 27.10 kW | 25.80 kW |
| COP Tj = Tbiv | 2.49 | 1.72 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 26.90 kW | 25.50 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.17 | 1.51 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000 | 1.000 |
| WTOL | 58 °C | 58 °C |
| Poff | 22 W | 22 W |
| РТО | 22 W | 22 W |
| PSB | 22 W | 22 W |
| PCK | 38 W | 38 W |
| Supplementary Heater: Type of energy input | n/a | n/a |
| Supplementary Heater: PSUP | 4.10 kW | 29.00 kW |
| Annual energy consumption Qhe | 14894 kWh | 18669 kWh |

Cooling





| EN 14511-2 | |
|------------------|------------|
| | +7°C/+12°C |
| El input | 9.54 kW |
| Cooling capacity | 29.60 |
| EER | 3.10 |

EN 14825





| This information was generated by the Fir KE | +7°C/+12°C |
|--|------------|
| Pdesignc | 29.60 kW |
| SEER | 4.80 |
| Pdc Tj = 35°C | 29.60 kW |
| EER Tj = 35°C | 3.10 |
| Pdc Tj = 30°C | 21.70 kW |
| EER Tj = 30°C | 4.14 |
| Cdc | 1.000 |
| Pdc Tj = 25°C | 15.00 kW |
| EER Tj = 25°C | 5.00 |
| Cdc | 1.000 |
| Pdc Tj = 20°C | 16.19 kW |
| EER Tj = 20°C | 6.57 |
| Cdc | 1.000 |
| Poff | 22 W |
| РТО | o w |
| PSB | 28 W |
| PCK | o w |
| Annual energy consumption Qce | 3700 kWh |