

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	CTC GSi 12 1x230V	Reg. No.	012-074
Certificate Holder			
Name	Eneritech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Subtype title	CTC GSi 12 1x230V		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass of Refrigerant	2.3 kg		

Model: CTC GSi 12 1x230V

Configure model	
Model name	CTC GSi 12 1x230V
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No
Phase-out Date	25.10.2023

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.55 kW	6.20 kW
El input	1.29 kW	2.34 kW
COP	4.31	2.65

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	196 %	148 %
Prated	10.00 kW	12.00 kW
SCOP	5.10	3.90
Tbiv	-15 °C	-9 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.90 kW	10.60 kW
COP Tj = -7°C	4.37	2.96
Pdh Tj = +2°C	5.40 kW	6.50 kW
COP Tj = +2°C	5.25	3.90
Pdh Tj = +7°C	3.40 kW	4.20 kW
COP Tj = +7°C	5.75	4.55
Pdh Tj = 12°C	2.40 kW	2.30 kW
COP Tj = 12°C	6.10	5.24
Pdh Tj = Tbiv	11.80 kW	11.60 kW
COP Tj = Tbiv	3.68	2.73

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.00 kW	11.60 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.03	2.64
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.97	0.98
WTOL	65 °C	65 °C
Poff	23 W	23 W
PTO	0 W	0 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.40 kW
Annual energy consumption Q_{he}	4041 kWh	6369 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	204 %	152 %
Prated	9.50 kW	11.80 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	5.30	4.00
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.70 kW	7.13 kW
COP Tj = -7°C	5.15	3.66
Pdh Tj = +2°C	3.50 kW	4.30 kW
COP Tj = +2°C	5.65	4.38
Pdh Tj = +7°C	2.40 kW	2.70 kW
COP Tj = +7°C	6.06	5.04
Pdh Tj = 12°C	2.40 kW	2.30 kW
COP Tj = 12°C	6.06	5.33
Pdh Tj = Tbiv	9.50 kW	11.60 kW
COP Tj = Tbiv	4.21	2.68
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.50 kW	11.71 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.23	2.68
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.96	0.97
WTOL	65 °C	65 °C
Poff	23 W	23 W
PTO	0 W	0 W
PSB	23 W	23 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.10 kW
Annual energy consumption Q _{he}	4425 kWh	7225 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	96 %
COP	2.40
Heating up time	1:49 h:min
Standby power input	23.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	232 l

Colder Climate

EN 16147	
Declared load profile	XL
COP	2.40
Heating up time	1:49 h:min
Standby power input	70.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	232 l
Efficiency η_{DHW}	96 %