

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	DAIKIN ALTHERMA 3 R ECH2O 4KW (500L) (/A)		Reg. No.	011-1W0263
Certificate Holder				
Name	DAIKIN Europe N.V.			
Address	Zandvoordestraat 300		Zip	B-8400
City	Oostende		Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Name of testing laboratory	Wärmepumpen-Testzentrum WPZ			
Subtype title	DAIKIN ALTHERMA 3 R ECH2O 4KW (500L) (/A)			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R32			
Mass Of Refrigerant	1.5 kg			
Certification Date	17.08.2018			
Testing basis	HP KEYMARK certification scheme rules rev. 7			

Model: ERGA04DV / EHSX04P50D

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65
Indoor water flow rate	0.74 m ³ /h	0.60 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh		1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL	5.20 kW	4.00 kW
COP Tj = TOL	2.56	1.37
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.57
Heating up time	2:47 h:min
Standby power input	38.2 W
Reference hot water temperature	45.2 °C
Mixed water at 40°C	237 l

Model: ERGA04DV / EHSXB04P50D

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65
Indoor water flow rate	0.74 m ³ /h	0.60 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh		1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL	5.20 kW	4.00 kW
COP Tj = TOL	2.56	1.37
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.66
Heating up time	2:29 h:min
Standby power input	42.0 W
Reference hot water temperature	45.0 °C
Mixed water at 40°C	211 l

Model: ERGA04DVA / EHSX04P50D

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65
Indoor water flow rate	0.74 m ³ /h	0.60 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh		1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL	5.20 kW	4.00 kW
COP Tj = TOL	2.56	1.37
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.57
Heating up time	2:47 h:min
Standby power input	38.2 W
Reference hot water temperature	45.2 °C
Mixed water at 40°C	237 l

Model: ERGA04DVA / EHSXB04P50D

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65
Indoor water flow rate	0.74 m ³ /h	0.60 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh		1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL	5.20 kW	4.00 kW
COP Tj = TOL	2.56	1.37
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.66
Heating up time	2:29 h:min
Standby power input	42.0 W
Reference hot water temperature	45.0 °C
Mixed water at 40°C	211 l

Model: ERGA04EV / EHSX04P50D3

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65
Indoor water flow rate	0.74 m ³ /h	0.60 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh		1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL	5.20 kW	4.00 kW
COP Tj = TOL	2.56	1.37
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Cooling

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

This information was generated by the HP KEYMARK database on 17 Dec 2020

	+7°C/+12°C
P _{designc}	4.50 kW
SEER	5.66
P _{dc} T _j = 35°C	4.52 kW
EER T _j = 35°C	3.32
P _{dc} T _j = 30°C	3.14 kW
EER T _j = 30°C	5.11
C _{dc}	1.0
P _{dc} T _j = 25°C	2.43 kW
EER T _j = 25°C	6.69
C _{dc}	1.0
P _{dc} T _j = 20°C	2.50 kW
EER T _j = 20°C	8.24
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	480 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.57
Heating up time	2:47 h:min
Standby power input	38.2 W
Reference hot water temperature	45.2 °C
Mixed water at 40°C	237 l

Model: ERGA04EV / EHSXB04P50D3

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65
Indoor water flow rate	0.74 m ³ /h	0.60 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh		1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL	5.20 kW	4.00 kW
COP Tj = TOL	2.56	1.37
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Cooling

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

This information was generated by the HP KEYMARK database on 17 Dec 2020

	+7°C/+12°C
P _{designc}	4.50 kW
SEER	5.66
P _{dc} T _j = 35°C	4.52 kW
EER T _j = 35°C	3.32
P _{dc} T _j = 30°C	3.14 kW
EER T _j = 30°C	5.11
C _{dc}	1.0
P _{dc} T _j = 25°C	2.43 kW
EER T _j = 25°C	6.69
C _{dc}	1.0
P _{dc} T _j = 20°C	2.50 kW
EER T _j = 20°C	8.24
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	480 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.66
Heating up time	2:29 h:min
Standby power input	42.0 W
Reference hot water temperature	45.0 °C
Mixed water at 40°C	211 l

Model: ERGA04EVA / EHSX04P50D3

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65
Indoor water flow rate	0.74 m ³ /h	0.60 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh		1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL	5.20 kW	4.00 kW
COP Tj = TOL	2.56	1.37
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Cooling

EN 14825

This information was generated by the HP KEYMARK database on 17 Dec 2020

	+7°C/+12°C
P _{designc}	4.50 kW
SEER	5.66
P _{dc} T _j = 35°C	4.52 kW
EER T _j = 35°C	3.32
P _{dc} T _j = 30°C	3.14 kW
EER T _j = 30°C	5.11
C _{dc}	1.0
P _{dc} T _j = 25°C	2.43 kW
EER T _j = 25°C	6.69
C _{dc}	1.0
P _{dc} T _j = 20°C	2.50 kW
EER T _j = 20°C	8.24
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	480 kWh

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14511-2	
	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.57
Heating up time	2:47 h:min
Standby power input	38.2 W
Reference hot water temperature	45.2 °C
Mixed water at 40°C	237 l

Model: ERGA04EVA / EHSXB04P50D3

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65
Indoor water flow rate	0.74 m ³ /h	0.60 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh		1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL	5.20 kW	4.00 kW
COP Tj = TOL	2.56	1.37
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Cooling

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

This information was generated by the HP KEYMARK database on 17 Dec 2020

	+7°C/+12°C
P _{designc}	4.50 kW
SEER	5.66
P _{dc} T _j = 35°C	4.52 kW
EER T _j = 35°C	3.32
P _{dc} T _j = 30°C	3.14 kW
EER T _j = 30°C	5.11
C _{dc}	1.0
P _{dc} T _j = 25°C	2.43 kW
EER T _j = 25°C	6.69
C _{dc}	1.0
P _{dc} T _j = 20°C	2.50 kW
EER T _j = 20°C	8.24
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	480 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.66
Heating up time	2:29 h:min
Standby power input	42.0 W
Reference hot water temperature	45.0 °C
Mixed water at 40°C	211 l