

Page 1 of 10

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	ESTIA HWS-P805H8R	Reg. No.	011-1W0346
Certificate Holder			
Name TOSHIBA AIR CONDITIONING			
Address	Porsham Close, Belliver Industrial Estate	Zip	PL6 7DB
City	Plymouth	Country	United Kingdom
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	ESTIA HWS-P805H8R		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.7 kg		
Certification Date	26.11.2019		



Model: HWS-P805H8R-E/HWS-P805XWHM3-E

Configure model		
Model name HWS-P805H8R-E/HWS-P805XWHM3-E		
Application Heating (medium temp)		
Units Indoor + Outdoor		
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Average Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	41 dB(A)	41 dB(A)	
Sound power level outdoor	66 dB(A)	66 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	169 %	123 %	
Prated	11.00 kW	10.00 kW	
SCOP	4.31	3.16	
Tbiv	-7 °C	-7 °C	
TOL	-9 °C	-9 °C	
Pdh Tj = -7°C	9.90 kW	9.10 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was general	The state of the s	TRACE OF TO MAI 202.
COP Tj = -7°C	2.90	2.01
Pdh Tj = +2°C	5.90 kW	6.00 kW
$COP Tj = +2^{\circ}C$	4.15	3.06
Pdh Tj = $+7^{\circ}$ C	4.00 kW	3.60 kW
$COP Tj = +7^{\circ}C$	5.73	4.13
Pdh Tj = 12°C	4.40 kW	4.20 kW
COP Tj = 12°C	7.51	6.32
Pdh Tj = Tbiv	9.90 kW	9.10 kW
COP Tj = Tbiv	2.90	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.80 kW	7.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.70	1.69
Rated airflow rate	5310 m³/h	5310 m³/h
WTOL	60 °C	60 °C
Poff	20 W	20 W
РТО	80 W	80 W
PSB	20 W	20 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.00 kW	10.00 kW
Annual energy consumption Qhe	5372 kWh	6750 kWh

Heating



EN 14511-2				
Low temperature Medium temperature				
Heat output	8.00 kW	7.26 kW		
El input	1.71 kW	2.56 kW		
СОР	4.68	2.84		

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Model: HWS-P805H8R-E/HWS-P805XWHT6-E

Configure model		
Model name HWS-P805H8R-E/HWS-P805XWHT6-E		
Application Heating (medium temp)		
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility Yes		
Cooling mode application (optional)	n/a	


General Data		
Power supply	Power supply 1x230V 50Hz	

Average Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	41 dB(A)	41 dB(A)	
Sound power level outdoor	66 dB(A)	66 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	169 %	123 %	
Prated	11.00 kW	10.00 kW	
SCOP	4.31	3.16	
Tbiv	-7 °C	-7 °C	
TOL	-9 °C	-9 °C	
Pdh Tj = -7°C	9.90 kW	9.10 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = -7°C	2.90	2.01
Pdh Tj = +2°C	5.90 kW	6.00 kW
COP Tj = +2°C	4.15	3.06
Pdh Tj = +7°C	4.00 kW	3.60 kW
$COP Tj = +7^{\circ}C$	5.73	4.13
Pdh Tj = 12°C	4.40 kW	4.20 kW
COP Tj = 12°C	7.51	6.32
Pdh Tj = Tbiv	9.90 kW	9.10 kW
COP Tj = Tbiv	2.90	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.80 kW	7.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.70	1.69
Rated airflow rate	5310 m³/h	5310 m³/h
WTOL	60 °C	60 °C
Poff	20 W	20 W
РТО	80 W	80 W
PSB	20 W	20 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.00 kW	10.00 kW
Annual energy consumption Qhe	5372 kWh	6750 kWh

Heating



EN 14511-2		
	Low temperature	Medium temperature
Heat output	8.00 kW	7.26 kW
El input	1.71 kW	2.56 kW
СОР	4.68	2.84

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	



Model: HWS-P805H8R-E/HWS-P805XWHT9-E

Configure model			
Model name	HWS-P805H8R-E/HWS-P805XWHT9-E		
Application	Heating (medium temp)		
Units	Indoor + Outdoor		
Climate Zone	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply 1x230V 50Hz		

Average Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	41 dB(A)	41 dB(A)	
Sound power level outdoor	66 dB(A)	66 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	169 %	123 %
Prated	11.00 kW	10.00 kW
SCOP	4.31	3.16
Tbiv	-7 °C	-7 °C
TOL	-9 °C	-9 °C
Pdh Tj = -7°C	9.90 kW	9.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = -7°C	2.90	2.01
Pdh Tj = +2°C	5.90 kW	6.00 kW
COP Tj = +2°C	4.15	3.06
Pdh Tj = $+7^{\circ}$ C	4.00 kW	3.60 kW
$COP Tj = +7^{\circ}C$	5.73	4.13
Pdh Tj = 12°C	4.40 kW	4.20 kW
COP Tj = 12°C	7.51	6.32
Pdh Tj = Tbiv	9.90 kW	9.10 kW
COP Tj = Tbiv	2.90	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.80 kW	7.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.70	1.69
Rated airflow rate	5310 m³/h	5310 m³/h
WTOL	60 °C	60 °C
Poff	20 W	20 W
РТО	80 W	80 W
PSB	20 W	20 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.00 kW	10.00 kW
Annual energy consumption Qhe	5372 kWh	6750 kWh
	i .	

Heating



 $$\operatorname{Page}\ 10$$ of 10 This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14511-2		
	Low temperature	Medium temperature
Heat output	8.00 kW	7.26 kW
El input	1.71 kW	2.56 kW
СОР	4.68	2.84

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	