

Page 1 of 10

This information was generated by the HP KEYMARK database on 6 Jul 2022

Login

Summary of	WZSV 42	Reg. No.	041-K001-50	
Certificate Holder	<u> </u>			
Name	ait-deutschland Gmb	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359	
City	Kasendorf	Country	Germany	
Certification Body	BRE Global Limited	BRE Global Limited		
Subtype title	WZSV 42	WZSV 42		
Heat Pump Type	Brine/Water			
Refrigerant	R410A	R410A		
Mass of Refrigerant	0.9 kg	0.9 kg		
Certification Date	21.06.2022	21.06.2022		
Testing basis	Heat Pump Keymark Scheme Rules Rev 09			



Model: alpha innotec - WZSV 42K3M

Configure model		
Model name	alpha innotec - WZSV 42K3M	
Application	Heating (medium temp)	
Units	Indoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.86 kW	3.51 kW
El input	0.89 kW	1.25 kW
СОР	4.34	2.81

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	192 %	135 %
Prated	3.90 kW	4.20 kW
SCOP	5.01	3.56
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.46 kW	3.58 kW
$COPTj = -7^{\circ}C$	4.44	3.04
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	2.07 kW	2.18 kW
COP Tj = +2°C	5.18	3.60
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	1.42 kW	1.48 kW
$COPTj = +7^{\circ}C$	5.59	3.98
Cdh Tj = +7 °C	1.000	1.000
Pdh Tj = 12°C	1.42 kW	1.36 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



COP Tj = 12°C	5.85	4.72
Cdh Tj = +12 °C	0.950	0.960
Pdh Tj = Tbiv	3.86 kW	3.58 kW
COP Tj = Tbiv	4.34	3.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.86 kW	3.51 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.34	2.81
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	55 °C	55 °C
Poff	12 W	12 W
РТО	44 W	44 W
PSB	12 W	12 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.70 kW
Annual energy consumption Qhe	1610 kWh	2436 kWh

Model: alpha innotec - WZSV 42K3MC

Configure model		
Model name	alpha innotec - WZSV 42K3MC	
Application	Heating (medium temp)	
Units	Indoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.86 kW	3.51 kW
El input	0.89 kW	1.25 kW
СОР	4.34	2.81

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	192 %	135 %
Prated	3.90 kW	4.20 kW
SCOP	5.01	3.56
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.46 kW	3.58 kW
$COPTj = -7^{\circ}C$	4.44	3.04
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	2.07 kW	2.18 kW
COP Tj = +2°C	5.18	3.60
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	1.42 kW	1.48 kW
$COPTj = +7^{\circ}C$	5.59	3.98
Cdh Tj = +7 °C	1.000	1.000
Pdh Tj = 12°C	1.42 kW	1.36 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 7 of 10

This information was generated by the HP KEYMARK database on 6 Jul 2022

5.85	4.72
0.950	0.960
3.86 kW	3.58 kW
4.34	3.04
3.86 kW	3.51 kW
4.34	2.81
1.000	1.000
55 °C	55 °C
12 W	12 W
44 W	44 W
12 W	12 W
0 W	0 W
Electricity	Electricity
0.00 kW	0.70 kW
1610 kWh	2436 kWh
	0.950 3.86 kW 4.34 3.86 kW 4.34 1.000 55 °C 12 W 44 W 12 W 0 W Electricity 0.00 kW

Model: NOVELAN - WSV 4.2K3M

Configure model			
Model name	NOVELAN - WSV 4.2K3M		
Application	Heating (medium temp)		
Units	Indoor		
Climate Zone	n/a		
Reversibility	No		
Cooling mode application (optional)	n/a		

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	3.86 kW	3.51 kW	
El input	0.89 kW	1.25 kW	
СОР	4.34	2.81	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	


Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	192 %	135 %
Prated	3.90 kW	4.20 kW
SCOP	5.01	3.56
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.46 kW	3.58 kW
$COPTj = -7^{\circ}C$	4.44	3.04
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	2.07 kW	2.18 kW
COP Tj = +2°C	5.18	3.60
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	1.42 kW	1.48 kW
$COPTj = +7^{\circ}C$	5.59	3.98
Cdh Tj = +7 °C	1.000	1.000
Pdh Tj = 12°C	1.42 kW	1.36 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C	5.85	4.72
Cdh Tj = +12 °C	0.950	0.960
Pdh Tj = Tbiv	3.86 kW	3.58 kW
COP Tj = Tbiv	4.34	3.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.86 kW	3.51 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.34	2.81
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	55 °C	55 °C
Poff	12 W	12 W
РТО	44 W	44 W
PSB	12 W	12 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.70 kW
Annual energy consumption Qhe	1610 kWh	2436 kWh