

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	CTC GSi 8	Reg. No.	012-SC0346-19
Certificate Holder			
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Name of testing laboratory	DTI, RISE		
Subtype title	CTC GSi 8		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass Of Refrigerant	2.4 kg		
Certification Date	05.11.2019		

Model: CTC GSi 8

General Data

Power supply	3x400V 50Hz
Off-peak product	No

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	6.08 kW	5.24 kW
El input	1.27 kW	1.78 kW
COP	4.78	2.95
Indoor water flow rate	1.20 m ³ /h	0.90 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	34 dB(A)	34 dB(A)

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825		
	Low temperature	Medium temperature
η_s	208 %	159 %
Prated	7.00 kW	7.00 kW
SCOP	5.39	4.17
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.02 kW	6.58 kW
COP Tj = -7°C	4.75	3.02
Cdh	0.98	0.99
Pdh Tj = +2°C	3.61 kW	4.31 kW
COP Tj = +2°C	5.68	4.71
Cdh	0.96	0.97
Pdh Tj = +7°C	2.47 kW	2.30 kW
COP Tj = +7°C	5.97	4.46
Cdh	0.94	0.94
Pdh Tj = 12°C	2.58 kW	2.28 kW
COP Tj = 12°C	6.05	4.86
Cdh	0.95	0.95
Pdh Tj = Tbiv	7.32 kW	6.91 kW
COP Tj = Tbiv	4.56	2.66

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	7.32 kW	6.87 kW
COP Tj = TOL	4.56	2.84
Cdh	0.97	0.97
WTOL	65 °C	65 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	0 W	0 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2683 kWh	3467 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	34 dB(A)	34 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	217 %	162 %
Prated	7.00 kW	7.00 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	5.63	4.24
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.18 kW	4.42 kW
COP Tj = -7°C	5.52	4.01
Cdh	0.97	0.98
Pdh Tj = +2°C	2.70 kW	2.33 kW
COP Tj = +2°C	6.11	4.59
Cdh	0.95	0.96
Pdh Tj = +7°C	2.64 kW	2.35 kW
COP Tj = +7°C	6.14	5.15
Cdh	0.95	0.95
Pdh Tj = 12°C	2.64 kW	2.68 kW
COP Tj = 12°C	6.14	5.92
Cdh	0.95	0.95
Pdh Tj = Tbiv	7.32 kW	6.94 kW
COP Tj = Tbiv	4.56	2.88
Pdh Tj = TOL	7.32 kW	6.87 kW
COP Tj = TOL	4.56	2.84
Cdh	0.97	0.97
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 17 Dec 2020

Poff	23 W	23 W
PTO	23 W	23 W
PSB	0 W	0 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	3063 kWh	4065 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	98 %
COP	2.39
Heating up time	01:58 h:min
Standby power input	79.8 W
Reference hot water temperature	49.8 °C
Mixed water at 40°C	239 l

Colder Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	98 %
COP	2.39
Heating up time	01:58 h:min
Standby power input	79.8 W
Reference hot water temperature	49.8 °C
Mixed water at 40°C	239 l