

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	FDCW100VNX-A	Reg. No.	012-SC0826-18
Certificate Holder			
Name	Mitsubishi Heavy Industries Air Conditioning Europe		
Address	5 The Square	Zip	UB11 1ET
City	Uxbridge, Middlesex	Country	United Kingdom
Certification Body	RISE CERT		
Name of testing laboratory	RISE		
Subtype title	FDCW100VNX-A		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	2.9 kg		

Model: FDCW100VNX-A + HMK100

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	5.21 kW	4.73 kW
El input	1.09 kW	1.54 kW
COP	4.78	3.07
Indoor water flow rate	0.89 m ³ /h	0.51 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	174 %	132 %
Prated	11.50 kW	10.00 kW
SCOP	4.42	3.37
Tbiv	-7 °C	-8 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.30 kW	8.90 kW
COP Tj = -7°C	2.91	1.99
Pdh Tj = +2°C	6.30 kW	5.50 kW
COP Tj = +2°C	4.34	3.22
Pdh Tj = +7°C	4.10 kW	3.50 kW
COP Tj = +7°C	5.51	4.61
Pdh Tj = 12°C	4.80 kW	5.00 kW
COP Tj = 12°C	6.96	6.25
Pdh Tj = Tbiv	10.20 kW	9.20 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP $T_j = T_{biv}$	2.89	1.90
P _{dh} $T_j = TOL$	9.30 kW	8.10 kW
COP $T_j = TOL$	2.66	1.92
C _{dh}	0.97	0.98
WTOL	65 °C	65 °C
P _{off}	2 W	2 W
PTO	20 W	15 W
PSB	15 W	15 W
PCK	35 W	35 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	2.20 kW	1.90 kW
Annual energy consumption Q _{he}	5482 kWh	6136 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	98 %
COP	2.32
Heating up time	1:00 h:min
Standby power input	85.0 W
Reference hot water temperature	51.0 °C
Mixed water at 40°C	230 l

Model: FDCW100VNX-A + HSB100

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	5.21 kW	4.73 kW
El input	1.09 kW	1.54 kW
COP	4.78	3.07
Indoor water flow rate	0.89 m ³ /h	0.51 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	174 %	132 %
Prated	11.50 kW	10.00 kW
SCOP	4.42	3.37
Tbiv	-7 °C	-8 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.30 kW	8.90 kW
COP Tj = -7°C	2.91	1.99
Pdh Tj = +2°C	6.30 kW	5.50 kW
COP Tj = +2°C	4.34	3.22
Pdh Tj = +7°C	4.10 kW	3.50 kW
COP Tj = +7°C	5.51	4.61
Pdh Tj = 12°C	4.80 kW	5.00 kW
COP Tj = 12°C	6.96	6.25
Pdh Tj = Tbiv	10.20 kW	9.20 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP $T_j = T_{biv}$	2.89	1.90
P _{dh} $T_j = TOL$	9.30 kW	8.10 kW
COP $T_j = TOL$	2.66	1.92
C _{dh}	0.97	0.98
WTOL	65 °C	65 °C
P _{off}	2 W	2 W
PTO	20 W	15 W
PSB	15 W	15 W
PCK	35 W	35 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	2.20 kW	1.90 kW
Annual energy consumption Q _{he}	5482 kWh	6136 kWh