

Page 1 of 4

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	Buderus Logatherm WPS 48.2 HT	Reg. No.	011-1W0163	
Certificate Holder				
Name	Bosch Thermotechnik GmbH (Buderus)			
Address	Sophienstraße 30-32	Zip	35576	
City	Wetzlar	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Subtype title	Buderus Logatherm WPS 48.2 HT			
Heat Pump Type	Brine/Water			
Refrigerant	R410A			
Mass of Refrigerant	7.5 kg			



This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: Buderus Logatherm WPS 48.2 HT

Configure model			
Model name	Buderus Logatherm WPS 48.2 HT		
Application	Heating (medium temp)		
Units	Indoor		
Climate Zone	n/a		
Reversibility	No		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	47.37 kW	47.69 kW	
El input	10.86 kW	15.39 kW	
СОР	4.36	3.10	

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	

Average Climate



This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	195 %	162 %
Prated	45.00 kW	47.00 kW
SCOP	5.07	4.24
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	39.81 kW	41.58 kW
COP Tj = -7°C	4.55	3.54
Pdh Tj = +2°C	25.31 kW	25.48 kW
COP Tj = +2°C	5.17	4.30
Pdh Tj = +7°C	25.32 kW	25.48 kW
COP Tj = +7°C	5.26	4.57
Pdh Tj = 12°C	25.32 kW	25.49 kW
COP Tj = 12°C	5.32	4.80
Pdh Tj = Tbiv	47.37 kW	47.69 kW
COP Tj = Tbiv	4.36	3.10

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	47.37 kW	47.69 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.36	3.10
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	68 °C	68 °C
Poff	25 W	25 W
РТО	25 W	25 W
PSB	25 W	25 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	18351 kWh	22882 kWh