

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	F1x45-12 1x230	Reg. No.	012-044
Certificate Holder			
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Subtype title	F1x45-12 1x230		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass of Refrigerant	2 kg		

Model: F1145-12 1x230

Configure model	
Model name	F1145-12 1x230
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.60 kW	10.97 kW
El input	2.72 kW	3.78 kW
COP	4.26	2.90

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	136 %
Prated	14.00 kW	14.00 kW
SCOP	4.58	3.60
Tbiv	-6 °C	-4 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.70 kW	10.80 kW
COP Tj = -7°C	4.51	3.16
Pdh Tj = +2°C	11.80 kW	11.10 kW
COP Tj = +2°C	4.70	3.68
Pdh Tj = +7°C	11.90 kW	11.40 kW
COP Tj = +7°C	4.86	3.97
Pdh Tj = 12°C	12.00 kW	11.60 kW
COP Tj = 12°C	4.89	4.24
Pdh Tj = Tbiv	11.70 kW	10.90 kW
COP Tj = Tbiv	4.55	3.35

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.60 kW	10.60 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.38	2.98
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.99	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	30 W	30 W
PSB	7 W	7 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	3.40 kW
Annual energy consumption Q_{he}	6322 kWh	8040 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	181 %	139 %
Prated	14.00 kW	14.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	4.73	3.68
Tbiv	-16 °C	-14 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	11.80 kW	11.00 kW
COP Tj = -7°C	4.77	3.59
Pdh Tj = +2°C	11.90 kW	11.30 kW
COP Tj = +2°C	4.88	3.90
Pdh Tj = +7°C	12.00 kW	11.50 kW
COP Tj = +7°C	4.94	4.18
Pdh Tj = 12°C	12.00 kW	11.70 kW
COP Tj = 12°C	4.71	4.30
Pdh Tj = Tbiv	11.70 kW	10.90 kW
COP Tj = Tbiv	4.60	3.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.60 kW	10.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.38	2.98
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	30 W	30 W
PSB	7 W	7 W
PCK	30 W	30 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	2.40 kW
Annual energy consumption Q _{he}	7313 kWh	9382 kWh

Model: F1245-12 1x230

Configure model

Model name	F1245-12 1x230
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
Off-peak product	No

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.60 kW	10.97 kW
El input	2.72 kW	3.78 kW
COP	4.26	2.90

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	136 %
Prated	14.00 kW	14.00 kW
SCOP	4.58	3.60
Tbiv	-6 °C	-4 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.70 kW	10.80 kW
COP Tj = -7°C	4.51	3.16
Pdh Tj = +2°C	11.80 kW	11.10 kW
COP Tj = +2°C	4.70	3.68
Pdh Tj = +7°C	11.90 kW	11.40 kW
COP Tj = +7°C	4.86	3.97
Pdh Tj = 12°C	12.00 kW	11.60 kW
COP Tj = 12°C	4.89	4.24
Pdh Tj = Tbiv	11.70 kW	10.90 kW
COP Tj = Tbiv	4.55	3.35

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.60 kW	10.60 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.38	2.98
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.99	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	30 W	30 W
PSB	7 W	7 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	3.40 kW
Annual energy consumption Q_{he}	6322 kWh	8040 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	181 %	139 %
Prated	14.00 kW	14.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	4.73	3.68
Tbiv	-16 °C	-14 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	11.80 kW	11.00 kW
COP Tj = -7°C	4.77	3.59
Pdh Tj = +2°C	11.90 kW	11.30 kW
COP Tj = +2°C	4.88	3.90
Pdh Tj = +7°C	12.00 kW	11.50 kW
COP Tj = +7°C	4.94	4.18
Pdh Tj = 12°C	12.00 kW	11.70 kW
COP Tj = 12°C	4.71	4.30
Pdh Tj = Tbiv	11.70 kW	10.90 kW
COP Tj = Tbiv	4.60	3.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.60 kW	10.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.38	2.98
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	30 W	30 W
PSB	7 W	7 W
PCK	30 W	30 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	2.40 kW
Annual energy consumption Q _{he}	7313 kWh	9382 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	96 %
COP	2.40
Heating up time	0:58 h:min
Standby power input	55.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	230 l

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	96 %
COP	2.40
Heating up time	0:58 h:min
Standby power input	55.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	230 l