

 $$\operatorname{\textit{Page}}\ 1$$ of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

	ins information was generated by		
Summary of	MONO AWHP 11 TR	Reg. No.	037-0004-18
Certificate Holder	!		-
Name	Remeha		
Address		Zip	
City		Country	Netherlands
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Name of testing laboratory	IGE Institut für GebäudeEnergetik		
Subtype title	MONO AWHP 11 TR		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	3.3 kg		
Certification Date	15.10.2018		
Testing basis	HP Keymark scheme rules rev. no. 4		



This information was generated by the HP KEYMARK database on 17 Dec 2020

Model: MONO AWHP 11 TR

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.20 kW	11.20 kW
El input	2.47 kW	4.15 kW
СОР	4.54	2.70
Indoor water flow rate	1.93 m³/h	1.20 m³/h

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

Average Climate



This information was generated by the HP KEYMARK database on 17 Dec 2020

	EN 12102-1		
	Low temperature	Medium temperature	
Sound power level outdoor	60 dB(A)	60 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	169 %	132 %	
Prated	10.00 kW	10.00 kW	
SCOP	4.29	3.37	
Tbiv	-7 °C	-7 °C	
TOL	-20 °C	-20 °C	
Pdh Tj = -7°C	8.90 kW	9.00 kW	
COP Tj = -7°C	3.17	1.99	
Pdh Tj = +2°C	5.40 kW	5.70 kW	
COP Tj = +2°C	4.24	3.30	
Pdh Tj = +7°C	3.60 kW	4.70 kW	
COP Tj = +7°C	5.31	4.86	
Pdh Tj = 12°C	4.30 kW	4.10 kW	
COP Tj = 12°C	7.66	6.35	
Pdh Tj = Tbiv	8.90 kW	9.00 kW	
COP Tj = Tbiv	3.17	1.99	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}4 of 4$ This information was generated by the HP KEYMARK database on 17 Dec 2020$

Pdh Tj = TOL	6.50 kW	6.50 kW
COP Tj = TOL	1.38	1.45
Cdh	0.95	0.96
WTOL	60 °C	60 °C
Poff	22 W	22 W
РТО	22 W	22 W
PSB	22 W	22 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.70 kW	1.60 kW
Annual energy consumption Qhe	4644 kWh	5968 kWh